



Carolina Power & Light Company
P. O. Box 10429
Southport, NC 28461

August 16, 1995

SERIAL: BSEP 95-0422

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DOCKET NO. 50-325 / LICENSE NO. DPR-71
IN-SERVICE INSPECTION REPORT

Gentlemen:

The purpose of this letter is to submit, in accordance with Technical Specification 4.0.5 and the reporting requirements of the ASME Boiler and Pressure Vessel Code, Section XI, Article IWA-6220(b), the Brunswick Steam Electric Plant, Unit 1 In-Service Inspection results. These examinations were performed from February 24, 1994 to May 21, 1995 (the end of the Brunswick Unit 1 Refuel Outage 9) to satisfy a portion of the periodic second inspection interval requirements using the ASME Code, Section XI, 1980 Edition through the Winter 1981 Addenda.

In addition, there was no submittal made for Brunswick Unit 1 IGSCC inspection results because no new indications or significant growth in existing indications were identified. This is in accordance with the guidance provided in Generic Letter 88-01.

Please refer any questions regarding this submittal to Mr. G. Honma at (910) 457-2741.

Sincerely,

G. D. Hicks
Manager - Regulatory Affairs
Brunswick Nuclear Plant

SHC/shc

Enclosure

cc: Mr. S. D. Ebner, NRC Region II, Regional Administrator
Mr. D. C. Trimble, NRC/NRR Project Manager - Brunswick
Mr. C. A. Patterson, NRC Senior Resident Inspector - Brunswick
Mr. Billy Walker, Assistant Director - Boiler & Pressure Vessel Division
The Honorable H. Wells, Chairman - North Carolina Utilities Commission

9508230282 950816
PDR ADDCK 05000325
Q PDR

AD471