



PECO ENERGY

GL 88-01, Supplement 1

PECO Energy Company  
Nuclear Group Headquarters  
965 Chesterbrook Boulevard  
Wayne, PA 19087-5691

August 16, 1995

Docket Nos. 50-277  
50-278

License Nos. DPR-44  
DPR-56

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Subject: Peach Bottom Atomic Power Station, Units 2 and 3  
Generic Letter 88-01, Supplement 1, "NRC Position on  
Intergranular Stress Corrosion Cracking (IGSCC) in BWR  
Austenitic Stainless Steel Piping"

Reference: 1) Letter from G. A. Hunger, Jr. (PECO Energy Company) to  
U. S. Nuclear Regulatory Commission (USNRC), dated May  
24, 1995

2) Letter from G. A. Hunger, Jr. (PECO Energy Company) to  
USNRC, dated August 9, 1995

Dear Sir:

In the Reference 1 letter, PECO Energy Company requested approval to reduce our Generic Letter (GL) 88-01, Supplement 1 ("NRC Position on Intergranular Stress Corrosion Cracking (IGSCC) in BWR Austenitic Stainless Steel Piping") actions by eliminating inspections of the RWCU System welds outboard of the primary containment isolation valves. In the Reference 2 letter, PECO Energy Company provided a response to a request for additional information on this subject. As a result of a conference call on August 15, 1995 to discuss our response, PECO Energy is supplying further information.

As stated in the Reference 2 letter in our response to question Number 4, currently available EPRI information regarding globe valves under blowdown conditions does not apply to the PECO Energy Anchor Darling globe valves.

9508230299 950816  
PDR ADDCK 05000277  
P PDR

AD18/10

August 16, 1995

Page 2

However, it is our understanding that EPRI is attempting to collect additional test data to provide further information on this issue. PECO Energy will review this further information and take actions, as appropriate, after the information becomes available.

If you have any questions, please contact us.

Very truly yours,

*G. A. Hunger, Jr.*

G. A. Hunger, Jr.  
Director - Licensing

cc: T. T. Martin, Administrator, Region I, USNRC  
W. L. Schmidt, USNRC Senior Resident Inspector, PBAPS