

DOCUMENT RETENTION	
Permanently	<input checked="" type="checkbox"/>
Facility Life	<input checked="" type="checkbox"/>
Other	<input type="checkbox"/>

WISCONSIN MICHIGAN POWER COMPANY
WISCONSIN ELECTRIC POWER COMPANY

POINT BEACH nuclear plant
TWO CREEKS, WIS.

POSTAL ROUTE 3, TWO RIVERS, WISCONSIN 54241

March 31, 1975

50-2664
SD-301

Mr. D. C. Boyd, Resident Inspector
U.S. Nuclear Regulatory Commission
Directorate of Regulatory Operations
2500 Garfield Street
Two Rivers, Wisconsin 54241


Dear Mr. Boyd:

In compliance with the requirements of 10 CFR 20,
Paragraph 20.205(b)(2), the following information is forwarded:

Nuclear Assurance Corporation spent fuel shipping
cask number 1D received at Point Beach Nuclear
Plant on March 28, 1975, was found to be in
excess of 29,000 dpm/100 cm² removable contamination
on the cask surface.

Very truly yours,

WISCONSIN MICHIGAN POWER COMPANY



Manager - Nuclear Power Division

Glenn A. Reed

faf

Submitted at 0815 hours, 3-31-75

Telecopying completed at 0850.

8403260267 750331
PDR ADOCK 05000266
S PDR