

POINT
BEACH nuclear plant

TWO CHELKS WIS

POSTAL ROUTE 3, TWO RIVERS, WISCONSIN 54241

April 1, 1975

50-266K

50-301

Mr. D. C. Boyd, Resident Inspector
Directorate of Regulatory Operations
U.S. Nuclear Regulatory Commission
2500 Garfield Street
Two Rivers, Wisconsin 54241

Dear Mr. Boyd:

In compliance with the requirements of 10 CFR 20,
paragraph 20.205(b)(2), the following information is forwarded:

Nuclear Assurance Corporation spent fuel shipping
cask number 1C, received at Point Beach Nuclear
Plant on March 28, 1975, was found to be in excess
of 22,000 dpm/100 cm² removable contamination on
the cask surface.

Very truly yours,

WISCONSIN MICHIGAN POWER COMPANY

Glenn A. Reed

Manager - Nuclear Power Division

Glenn A. Reed

faf

Submitted 4-1-75, 1240 hours

8403260272 750401
PDR ADCK 05000266
S PDR

50-266