

LICENSEE EVENT REPORT

50-285/76-11

CONTROL BLOCK:

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME														LICENSE NUMBER														LICENSE TYPE														EVENT TYPE			
01	N	E	F	C	S	1	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	3																					
7	8	9	14	15	25	26	30	31	32																																				
01		CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER				EVENT DATE				REPORT DATE																															
01	CON'T			L	L	0	5	0	-	0	2	8	5	0	4	0	7	7	6	0	5	0	3	7	6																				
7	8	57	58	59	60	61	68	69	74	75	80																																		

EVENT DESCRIPTION

02	During surveillance test of diesel to test operability. The start on secondary air																							
03	required 10.6 seconds (the limit is 10 seconds). Primary air start was immediately																							
04	tested and diesel was started in 8.2 seconds. Restart on secondary air required 8.1																							
05	seconds. Diesel was always operable, redundant diesel was operable also.																							
06																								

SYSTEM CODE				CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMP. MANUFAL				VIOLATION		
07	E	E		D		E	N	G	I	N	E	A		G	1	0	0	N
7	8	9	10	11	12	17	43	44	47	48								

CAUSE DESCRIPTION

08	Procedure was inadequate in that signoffs did not require specifically that the air																							
09	motor utilized for starting be consistently alternated from primary to secondary.																							
10																								

FACILITY STATUS				% POWER				OTHER STATUS				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION			
11	E			1	0	0		NA				B				Surveillance testing			
7	8	9	10	11	12	13	44	45	46	80									
FORM OF ACTIVITY RELEASED				CONTENT OF RELEASE				AMOUNT OF ACTIVITY				LOCATION OF RELEASE							
12	Z			Z				NA				NA							
7	8	9	10	11	44	45	80												

PERSONNEL EXPOSURES

NUMBER				TYPE		DESCRIPTION	
13	0	0	0	Z		NA	
7	8	9	11	12	13	80	

PERSONNEL INJURIES

NUMBER				DESCRIPTION	
14	0	0	0	NA	
7	8	9	11	12	80

OFFSITE CONSEQUENCES

15	None																							
7	8	9	80																					

LOSS OR DAMAGE TO FACILITY

TYPE				DESCRIPTION	
16	Z			NA	
7	8	9	10	80	

PUBLICITY

17	NA																							
7	8	9	80																					

ADDITIONAL FACTORS

18	NA																							
7	8	9	80																					

19																								
7	8	9	80																					

NAME: S. M. Moyers

PHONE: 402-426-4011



Omaha Public Power District

1623 HARNEY ■ OMAHA, NEBRASKA 68102 ■ TELEPHONE 536-4000 AREA CODE 402

May 4, 1976

FC-157-76

Mr. E. Morris Howard
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, TX 76012



Dear Mr. Howard:

Reference: Fort Calhoun Station Unit No. 1
Docket No. 50-285

In accordance with the Fort Calhoun Station's Technical Specifications, the Omaha Public Power District, as holder of facility operating license DPR-40, submits three copies of the following licensee event report 50-285/76-11 to satisfy the requirements of Regulatory Guide 1.16.

Sincerely,

W. C. Jones
Section Manager
Operations

WCJ/WDD:rge

Enclosure

cc: Director, Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, DC 20555 (3)

Director, Office of Inspection and
Enforcement
U. S. Nuclear Regulatory Commission
Washington, DC 20555 (30)

Mr. L. C. Shalla
SARC Chairman
PRC Chairman
Fort Calhoun File (2)

4720

COPY SENT REGION