



## State of New Jersey

Christine Todd Whitman  
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.  
Commissioner

Division of Environmental Safety, Health,  
Analytical Programs  
Radiation Protection Programs  
Bureau of Nuclear Engineering  
CN 415  
Trenton, NJ 08625-0415  
Tel: (609) 984-7700 FAX: (609) 984-7513

August 21, 1995

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Ladies & Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)  
Docket No. 50-219  
Snubber Visual Inspection Surveillance Interval  
(Section 4.5.Q.a), and Bases (Section 4.5)

By letter dated June 26, 1995, GPU Nuclear Corporation (GPUN) submitted to the U.S. Nuclear Regulatory Commission (NRC) Technical Specification Change Request (TSCR) No. 227.

The TSCR proposes to (a) revise the Snubber Visual Inspection surveillance intervals to match the schedule developed by the NRC staff for use with a 24 month refueling interval, and (b) revise the bases for the snubber visual inspection. These changes intend to make the TSCR consistent with the schedule and bases described in NRC Generic Letter 90-09.

The purpose of this change request is to amend the technical specification (TS) to not require the reactor shutdown between refueling outages in order to perform the inspections on the snubbers per existing TS frequency.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering (BNE) staff has reviewed GPUN's analysis concerning the determination of no significant hazards consideration of TSCR-227 and has concluded that the change request is in accordance with the guidance of GL 90-09.

9508250113 950821  
PDR ADDCK 05000219  
PDR

550020

New Jersey is an Equal Opportunity Employer  
Recycled Paper

ADD 1/0

If you have any questions please contact Rich Pinney at  
(609) 984-7558.

Sincerely,

*Kent Tosch / DJ.*

Kent Tosch, Manager  
Bureau of Nuclear Engineering

c: J. Lipoti, PhD., Assistant Director RPP -- NJ DEP  
D. Zannoni, Supervisor NES/BNE -- NJ DEP  
D. Chawaga, State Liaison, Region I -- US NRC  
L. Briggs, Senior Resident Inspector OCNGS -- US NRC  
M. Laggart, Licensing Manager -- GPUN