



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Hope Creek Generating Station

August 18, 1995

Chief George Corporale
Bureau of Information Systems
P. O. Box CN-029
Trenton, N. J. 08625

RE: NEW JERSEY POLLUTANT DISCHARGE
ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT
HOPE CREEK GENERATING STATION
NJPDES PERMIT NJ0025411

Dear Sir:

Attached is the Discharge Monitoring Report for the Hope Creek Generating Station for the month of July 1995.

This report is required by and prepared specifically for the Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analysis required to be performed by the above agencies. The choice of the measurement devices and analytical methods are controlled by the EPA and the NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or that any reading analytical result represents the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

If you have any questions concerning this report, please feel free to contact Mr. C. E. White.

Sincerely,

Mark E. Reddemann
General Manager -
Hope Creek Operations

250023

9508250146 950818
PDR ADDCK 05000354
R PDR

IFAS
11

me CW:eaj
Attachments

C Executive Director, DRBC
USNRC - Docket number 50-354

NJPDES
Explanation of conditions
July 1995

8/18/95

The following explanations are included to clarify possible deviation from permit conditions.

General - The columns labeled "No. Ex", on the enclosed DMR, tabulate the number of daily discharge values outside the indicated limits.

Data reporting and accuracy reflect the working environment, the design capabilities and reliability of the monitoring instruments and operating equipment.

Analytical values performed by the following NJDEP certified laboratories:

NET Atlantic, Inc. (08153)
Hope Creek Generating Station (17451)
Talbot Laboratory, Inc. (77535)
South Jersey Testing, Inc. (06431)
Princeton Testing Laboratory, Inc. (11118)

Deviations from required sampling, analysis monitoring and reporting methods and periodicities are noted on the respective transmittal sheet.

Frequency for discharge point 461A, the Cooling Tower Blowdown, and the River were done at approximately 5 hour intervals to provide for the cycles of concentration in the system.

As per the Administrative Consent Order the TSS limit for discharge points 462A, 463A and 464 have been lifted and the interim thermal limits for discharge point 461A have been changed to 443 MBTU/hr (June - September) and 731 MBTU/hr (October - May).

Results reported on the Discharge Monitoring Report forms are consistent with permit limits, data supplied from contract laboratories, the December 1993 revision of the NJDEP DMR Instruction manual and specific guidance from DEP personnel.

NJPDES
Explanation of Exceedances
July 1995

8/18/95

The following exceedances are included in the attached report and explained below. Exclusions have not endangered nor significantly impacted public health or the environment.

DSN No.


EXPLANATION

No Exceedances


COUNTY OF SALEM
STATE OF NEW JERSEY

I, Mark E. Reddemann, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am the General Manager of the Hope Creek Generating Station, and as such am authorized to sign Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.


Mark E. Reddemann
General Manager -
Hope Creek Operations

Sworn and subscribed before me
this 18th day of August 1995.



BETTY LOU McKEICH
NOTARY PUBLIC OF NEW JERSEY
MY COMMISSION EXPIRES DEC. 6, 1996

ADDENDA TO MONITORING REPORT - TRANSMITTAL SHEET

DISCHARGE NUMBER

PAGE	PARAMETER	COMMENTS
<u>461A</u>	CODE	
2 of 12	00665 2 1 ** 00680 2 1	Net values calculated from grab sample results.
<u>461C</u>		
6 of 12	00680 1 1 **	Samples obtained were composites in accordance with permit requirements.