

BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License)
of) Docket No. 50-267
PUBLIC SERVICE COMPANY OF COLORADO)

Application for Amendment to
Appendix A of Facility Operating License
License No. DPR-34

OF THE
PUBLIC SERVICE COMPANY OF COLORADO
FOR THE
FORT ST. VRAIN NUCLEAR GENERATING STATION

This application for Amendment to Appendix A of
Facility Operating License, License No. DPR-34,
is submitted for NRC review and approval.

Respectfully submitted,
PUBLIC SERVICE COMPANY OF COLORADO
By O. R. Lee, Vice President

KELLY, STANSFIELD & O'DONNELL
Bryant O'Donnell
Robert E. Thompson
Public Service Company Building
Denver, Colorado 80202

Attorneys for Applicant

8403270191 840314
PDR ADOCK 05000267
P PDR

ATTACHMENT 1

SUMMARY OF PROPOSED CHANGES

SUMMARY OF PROPOSED CHANGES

<u>Section</u>	<u>Description of Change</u>
LCO 4.4.1	<ol style="list-style-type: none">1) Deleted the time period for which the footnote to the action statement for Table 4.4-1 was to be effective. The footnote was added to the action statement so that the stated exception will be available whenever maintenance is necessary.2) Inserted the requirement for reestablishing channel operability immediately following the action statements for Tables 4.4-1 through 4.4-4. This paragraph was deleted from its previous location on page 4.4-15.3) Added statement to Note (f) for clarification.4) Corrected typographical error in Note (j).5) Replaced FSAR reference Section with more applicable Section.
LCO 4.4.2	<ol style="list-style-type: none">1) Corrected FSAR Amendment reference for Question 7.5.
LCO 4.4.5	<ol style="list-style-type: none">1) Modified specification to eliminate references to specific moisture monitors.2) Modified basis to reflect the specification change described above.