



**Florida
Power**
CORPORATION

March 26, 1984
3F0384-18

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating Licensing No. DPR-72
Notice of Violation of NPDES Permit By
the Environmental Protection Agency

Dear Sir:

Attached is a Notice of Violation of NPDES Permit Number FL0000159 received from the Environmental Protection Agency by Florida Power Corporation (FPC) and the FPC response to the violation. This violation concerns the reporting of heavy metal concentrations for discharges.

If there are any questions concerning this information, please contact this office.

Sincerely,

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

DVH/feb

Attachments

cc: Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30303

8403300111 840326
PDR ADDCK 05000302
S PDR

IE06
1/1



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET
ATLANTA, GEORGIA 30365

MA 6 30-7

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

REF: 4WM-FP

Mr. Walter S. Wilgus
Vice President, Nuclear Operations
Florida Power Corporation
P. O. Box 14042
St. Petersburg, Florida 33733

Re: Notice of Violation
NPDES Permit No. FL0000159

Dear Mr. Wilgus:

This is to advise you that your facility is in violation of the above-referenced NPDES permit as follows:

You did not report heavy metals concentrations for discharge serial number 009 for October. Since both ash ponds (004 and 009) discharged during October both must be monitored.

You are required to notify this Agency within fifteen (15) days of receipt of this letter of the action you have taken or will take to correct these violations. In addition, please monitor and report the following parameters (as required on page 2 of 15 of your permit).

The temperature of the condenser cooling water at the bulkhead line shall not exceed 39.4°C (103°F) for a period of more than three consecutive hours. (Outfalls 1, 2, and 5).

The temperature rise across the condenser of Unit 3 shall not exceed 9.7°C (17.5°F) for a period of more than three consecutive hours. (Outfall 5).

Attached is a Discharge Monitoring Report which indicates the proper way to enter data.

Until such time as you achieve compliance with all conditions of your NPDES permit, you are considered to be in violation of and subject to enforcement action pursuant to Section 309 of the Clean Water Act.