



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

34 MAR 28 1984
40, JACKSON, MISSISSIPPI 39205
March 21, 1984

NUCLEAR PRODUCTION DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 84-110/1 - Update
Report - Fire Door 1A320
Blocked Open to Support
Planned Activities
AECM-84/0186

This is an update to a previous report submitted on December 13, 1983. The condition for which the report was submitted occurred on November 10, 1983, when fire door 1A320 to the Main Steam Tunnel Room was blocked open to support planned maintenance and testing activities. Fire watches were established in accordance with Technical Specification 3.7.7. The condition was reported pursuant to Technical Specification 6.9.2.

The door was restored to operability on March 6, 1984. This is a final report.

Yours truly,

L. F. Dale

L. F. Dale
Manager of Nuclear Services

EBS/SHH:lm

cc: Mr. J. B. Richard Mr. R. B. McGehee
 Mr. T. B. Conner Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

DP1

Member Middle South Utilities System

8403300124 840321
PDR ADOCK 05000416
PDR

IE22
1/0