

UNIT SHUTDOWNS AND POWER REDUCTIONS

"CORRECTED COPY"

REPORT MONTH January, 1984

DOCKET NO. 50-389
 UNIT NAME St. Lucie Unit #2
 DATE 2-15-84
 COMPLETED BY N.W. Grant
 TELEPHONE (305) 552-3675

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
01	840119	F	6.7	A	3		HA	GENERA	Indication of generator ground; monitoring instrument malfunction.
02	840119	S	30.1	H	4		ZZ	ZZZZZZ	Previous outages extended for NRC required snubber inspection.
03	840121	F	0.0	H	5		HJ	ZZZZZZ	High steam generator chloride level caused power reduction.
04	840125	F	99.9	A	1		HF	XXXXXX	Intake cooling water traveling screen malfunction, due to large volume of jellyfish.

8403300193 840315
 PDR ADOCK 05000250
 R PDR

¹
 F Forced
 S Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)
 4- CONTINUED
 5- LOAD REDUCTION

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source