



## Duquesne Light

Nuclear Construction Division  
Robinson Plaza, Building 2, Suite 210  
Pittsburgh, PA 15205

2NRC-4-030  
(412) 787-5141  
(412) 923-1960  
Telecopy (412) 787-2629  
March 22, 1984

United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

ATTENTION: Dr. Thomas E. Murley  
Administrator


SUBJECT: Beaver Valley Power Station - Unit No. 2  
Docket No. 50-412  
Apparently Fraudulent Products Sold by Ray Miller  
IE Bulletin No. 83-07

Gentlemen:

Please find the attached summary of the actions taken in regards to the requirements of IE Bulletin 83-07. This response addresses the concerns of the Bulletin, and no additional correspondence will be made.

DUQUESNE LIGHT COMPANY

By


  
E.J. Woolever  
Vice President

JS/wjs  
Attachment

REFERENCE: IE Information Notice 83-01

cc: Mr. R. DeYoung, Director  
Office of Inspection and Enforcement (3) (w/a)  
NRC Document Control Desk (w/a)  
Mr. G. Walton, NRC Resident Inspector (w/a)  
Mr. M. Lacitra, Project Manager (w/a)  
INPO Records Center (w/a)

SUBSCRIBED AND SWORN TO BEFORE ME THIS  
22nd DAY OF March, 1984.



Notary Public

ANITA ELAINE REITER, NOTARY PUBLIC  
ROBINSON TOWNSHIP, ALLEGHENY COUNTY  
MY COMMISSION EXPIRES OCTOBER 20, 1986

8403300200 840322  
PDR ADOCK 05000412  
PDR

11  
TEL

COMMONWEALTH OF PENNSYLVANIA )  
 ) SS:  
COUNTY OF ALLEGHENY )

On this 22nd day of March, 1984, before me,  
a Notary Public in and for said Commonwealth and County, personally  
appeared E. J. Woolever, who being duly sworn, deposed and said that (1) he  
is Vice President of Duquesne Light, (2) he is duly authorized to execute  
and file the foregoing Submittal on behalf of said Company, and (3) the  
statements set forth in the Submittal are true and correct to the best of  
his knowledge.

Anita Elaine Reiter  
Notary Public

ANITA ELAINE REITER, NOTARY PUBLIC  
ROBINSON TOWNSHIP, ALLEGHENY COUNTY  
MY COMMISSION EXPIRES OCTOBER 20, 1986

"Apparently Fraudulent Products Sold by Ray Miller, Inc."

Duquesne Light Company's (DLC) NSSS Vendor, Westinghouse (W), and DLC's A/E, Stone & Webster Engineering Corporation (SWEC), have completed their reviews of the products supplied by Ray Miller. The results of these reviews indicate that two suppliers have received material from Ray Miller, Inc.

First, Pittsburgh-Des Moines Steel received blind flanges which were used in the containment building lightning rods. DLC has determined that the blind flange material is a different material than the fraudulent material supplied by Ray Miller, Inc.

Second, Joseph Oat Corporation received one section of 12" Schedule 40S, 304 stainless steel pipe, 3'-4" long. Ray Miller, Inc., had received this material from Swepco Tube Corp. and directly passed on the Swepco material certification to Joseph Oat Corporation.

Joseph Oat Corporation was not included in the NRC-identified list of apparently fraudulent materials. The supplied material was eventually used in the recirculating spray coolers. Because the material certification is from the original supplier (Swepco) and not Ray Miller, Inc., this material is considered to be accurately certified.

Based on the above, BVPS-2 believes that no additional action needs to be taken in reference to this bulletin.