



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

March 14, 1984  
(NMP2L 004)

Mr. R. W. Starostecki, Director  
U.S. Nuclear Regulatory Commission  
Region I  
Division of Project and Resident Programs  
631 Park Avenue  
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2  
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report in accordance with 10CFR50.55(e) for the problem concerning an hydraulic transient for pump restart in the service water system (55(e) - 84-09). This problem was reported via telecon to S. Collins of your staff on February 15, 1984.

Very truly yours,

C. V. Mangan  
Vice President  
Nuclear Engineering & Licensing

CVM/TL:ja  
Enclosure  
xc: Director of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

R. Gramm (NRC Resident Inspector)

8404030162 840314  
PDR ADOCK 05000410  
S PDR

IE27  
11

NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT - UNIT 2  
DOCKET NO. 50-410

Interim Report for a Problem  
Concerning Hydraulic Transient for Pump Restart  
(55(e) - 84-09)

Description of the Problem

The hydraulic transient for pump restart was not considered in the service water piping system analysis. As a result of problems in some operating plants, this condition was initially addressed by the Nuclear Regulatory Commission in NUREG 0582.

The matter is still under investigation and a final report will be submitted by September 28, 1984.