

**Florida
Power**
CORPORATION

March 30, 1984
3F0384-22

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
NUREG-0737, Item II.E.1.1
EFW Program: NRC Commitment Status Update

Dear Sir:

This letter provides a status update to Attachment I of the FPC letter dated October 7, 1983, titled Schedule For Completion of Seismic Upgrades to EFW System. Specifically, two responses from that attachment are provided as follows:

TER Page 4, Paragraph 5

(d) three loose items in the control complex electrical support room. The licensee will add steel angle braces where necessary, replace the missing clamp, and tighten all loose items. Such corrective actions will be accomplished as part of the overall AFW system upgrade. . .

TER Page 4, Paragraph 5 Response

(d) Gilbert Associates, Inc. is currently completing the necessary design packages to resolve these items. Corrective actions are scheduled for Refuel V.

TER Page 5, Paragraph 3

Additionally, the licensee also performed walkdown of the seismically qualified areas of the AFW system. Deficiencies were identified, corrective actions were proposed or are to be identified, and the schedule will be consistent with the overall AFW system upgrade as mentioned previously. Results of this walkdown are summarized below:

8404030279 840330
PDR ADOCK 05000302
P PDR

A046
1/0


March 30, 1984
3F0384-22
Page 2

Piping - (h) A lateral restraint, designed as removable support to allow future disassembly, will be added to one of the seal injection lines routed from the top of the turbine-driven pump casing to the valve EFV-51.

TER Page 5, Paragraph 3 Response

(h) Gilbert Associates, Inc. is currently performing a review of this piping to determine the extent of modifications necessary for seismic acceptability. Any modifications will be completed during Refuel V.

Sincerely,



G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

EMG/feb

cc: Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30303