



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

March 26, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Units 1 and 2
FSAR Changes Relating to the Startup
Test Program Table 14.2-123
NRC Docket Nos. 50-373 and 50-374

Reference (a): Telephone Conversation with Bill Long
(NRR) on March 5, 1984.

Dear Mr. Denton:

As a result of a review of the FSAR a clarification was determined to be necessary to Table 14.2-123 (Relief Valve Startup Test Abstract). The second paragraph in the description of the test abstract implies that the backpressure of the relief valve discharge lines will be measured during the Unit 1 Startup Test and the Unit 2 Startup Test. This backpressure was measured during the Unit 1 Test Program but will not be measured during the Unit 2 test program. The backpressure will not be monitored during the Unit 2 test because the instrumentation tapes required for the measurement which were installed on the Unit 1 piping, primarily for the Unit 1 In-Plant SRV Special Test, are not available on the Unit 2 piping. Justification for the omission of this measurement from the Unit 2 test is provided due to the fact that the relief valve discharge line piping arrangements are very similar between Unit 1 and Unit 2 and a large margin to the criteria was observed during the Unit 1 testing. Therefore, we have added a qualifying statement to the test abstract that indicates this particular measurement is only applicable to the Unit 1 Startup Test Program.

This change has been included in Amendment 64 of the FSAR and has been tentatively agreed upon via our telephone conversation with Bill Long on March 5, 1984.

In accordance with License NPF-18, Condition 2.C.17 it is requested that you document to us your official agreement with this change.

If there are any questions regarding this matter, please contact this office.

Very truly yours

8404030284 840326
PDR ADOCK 05000373
P PDR

CW Schroeder 3/26/84

C. W. Schroeder
Nuclear Licensing Administrator

lm

cc: NRC Resident Inspector - LSCS

8346N

IE26
1/0