

## LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
Washington Nuclear Project - Unit 2	05000397	84	010	00	03	OF	03

TEXT (If more space is required, use additional NRC Form 366A's) (17)

All five excess flow check valves (EFC) were removed, modified, bench tested and reinstalled. Each will be surveillance tested. A work request has been issued to modify the name tags of all EFC's. Drawings are being revised to indicate water or gas service.

8404040084 840328  
PDR ADOCK 05000397  
S PDR

## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397  
March 28, 1984

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: **NUCLEAR PROJECT NO. 2**  
**SUPPLEMENTAL REPORT TO LER 84-010-00**

Dear Sir:

Transmitted herewith is the supplement to the LER for WNP-2 Plant. Please change the page numbers of the original LER to reflect that there are now three pages rather than two.

Very truly yours,

*J. D. Martin*  
J. D. Martin (M/D 927M)  
WNP-2 Plant Manager

JDM:de

Enclosure:  
Supplemental Report to LER No. 84-010-00

cc: Mr. John B. Martin, Administrator  
Region V, Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane  
Walnut Creek, California 94596  
Mr. A. D. Toth, NRC Resident Inspector (901A)

TE22  
1/1