




PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Red Wing, Minnesota

UNITS 1 AND 2



ANNUAL REPORT

to the

UNITED STATES NUCLEAR REGULATORY COMMISSION

Radiation Environmental Monitoring Program

January 1, 1983 to December 31, 1983

NORTHERN STATES POWER COMPANY
MINNEAPOLIS, MINNESOTA

B404060197 B40330
PDR ABCK 05000282
R PDR

APR 3 1984

IES



MIDWEST LABORATORY

1509 FRONTAGE RD.

NORTHBROOK, IL 60062

(312) 564-0700

NORTHERN STATES POWER COMPANY
MINNEAPOLIS, MINNESOTA


PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket No. 50-282 License No. DPR-42
50-306 DPR-60

ANNUAL REPORT
to the
UNITED STATES NUCLEAR REGULATORY COMMISSION

Radiation Environmental Monitoring Program
January 1, 1983 to December 31, 1983

Prepared Under Contract
by
TELEDYNE ISOTOPES MIDWEST LABORATORY
Project No. 8010

Approved by:


L. G. Huebner
General Manager

6 February 1984

PREFACE

The staff of Teledyne Isotopes Midwest Laboratory (formerly Hazleton Environmental Sciences), was responsible for the acquisition of data presented in this report. Samples were collected by members of the staff of the Prairie Island Nuclear Generating Plant.

The report was prepared by L. G. Huebner, General Manager. He was assisted in the report preparation by L. Nicia, Group Leader, and D. Cohen, Scientist.

TABLE OF CONTENTS

| | <u>Page</u> |
|------------------------------------------------------------------------------------------------------------------------------|-------------|
| PREFACE | ii |
| List of Tables | iv |
| 1.0 INTRODUCTION | 1 |
| 2.0 SUMMARY | 2 |
| 3.0 RADIATION ENVIRONMENTAL MONITORING PROGRAM (REMP) | 3 |
| 3.1 Program Design and Data Interpretation | 3 |
| 3.2 Program Description | 4 |
| 3.3 Program Execution | 6 |
| 3.4 Laboratory Procedures | 6 |
| 3.5 Program Modifications | 7 |
| 3.6 Land Use Census | 7 |
| 4.0 RESULTS AND DISCUSSION | 9 |
| 4.1 Atmospheric Nuclear Detonations | 9 |
| 4.2 Program Findings | 9 |
| 5.0 TABLES | 13 |
| 6.0 REFERENCES CITED | 25 |
| APPENDICES | |
| A. Crosscheck Program Results | A-1 |
| B. Data Reporting Conventions | B-1 |
| C. Maximum Permissible Concentrations of Radioactivity in Air and Water Above Natural Background in Unrestricted Areas | C-1 |

List of Tables

| <u>No.</u> | <u>Title</u> | <u>Page</u> |
|------------|-------------------------------------------------------|-------------|
| 5.1 | Sample collection and analysis program, 1983 | 14 |
| 5.2 | Sampling locations | 16 |
| 5.3 | Missed collections and analyses, 1983 | 17 |
| 5.4 | Environmental Radiological Monitoring Program Summary | 18 |

In addition, the following tables are in the Appendix:

Appendix A

| | | |
|-----|--------------------------------------------------------------------|-----|
| A-1 | Crosscheck program results, milk and water samples, 1980-1983 | A-3 |
| A-2 | Crosscheck program results, thermoluminescent dosimeters (TLDs) | A-9 |

Appendix C

| | | |
|-----|---------------------------------------------------------------------------------------------------------------------------|-----|
| C-1 | Maximum permissible concentrations of radioactivity in air and water above natural background in unrestricted areas | C-2 |
|-----|---------------------------------------------------------------------------------------------------------------------------|-----|

1.0 INTRODUCTION

This report summarizes and interprets results of the Radiation Environmental Monitoring Program (REMP) conducted by Teledyne Isotopes Midwest Laboratory (formerly Hazleton Environmental Sciences) at the Prairie Island Nuclear Generating Plant, Red Wing, Minnesota, during the period January - December, 1983. This program monitors the levels of radioactivity in the air, terrestrial, and aquatic environments in order to assess the impact of the plant on its surroundings.

Tabulations of the individual analyses made during the year are not included in this report. These data are included in a reference document (Teledyne Isotopes Midwest Laboratory, 1984) available at Northern States Power Company, Nuclear Generation Department.

Prairie Island Nuclear Generating Plant is located on the Mississippi River in Goodhue County, Minnesota, and operated by Northern States Power Company. The plant has two 550 MWe pressurized water reactors. Unit 1 achieved initial criticality on 1 December 1973. Commercial operation at full power began on 16 December 1973. Unit 2 achieved initial criticality on 17 December 1974. Commercial operation at full power began on 21 December 1974.

2.0 SUMMARY

The Radiation Environmental Monitoring Program (REMP) required by the U.S. Nuclear Regulatory Commission (NRC) Technical Specifications for the Prairie Island Nuclear Generating Plant is described. Results for 1983 are summarized and discussed.

Program findings show background levels of radioactivity in the environmental samples collected in the vicinity of the Prairie Island Nuclear Generating Plant. No effect on the environment due to the operation of the Plant is indicated.

3.0 RADIATION ENVIRONMENTAL MONITORING PROGRAM (REMP)

3.1 Program Design and Data Interpretation

The purpose of the Radiation Environmental Monitoring Program (REMP) at the Prairie Island Nuclear Generating Plant is to assess the impact of the plant on its environment. For this purpose, samples are collected from the air, terrestrial, and aquatic environments and analyzed for radioactive content. In addition, ambient gamma radiation levels are monitored by thermoluminescent dosimeters (TLDs).

Sources of environmental radiation include the following:

- (1) natural background radiation arising from cosmic rays and primordial radionuclides;
- (2) fallout from atmospheric nuclear detonations;
- (3) releases from nuclear power plants.

In interpreting the data, effects due to the Plant must be distinguished from those due to other sources.

A major interpretive aid in assessment of these effects is the design of the monitoring program at the Prairie Island Plant which is based on the indicator-control concept. Most types of samples are collected both at indicator locations (nearby, downwind, or downstream) and at control locations (distant, upwind, or upstream). A plant effect would be indicated if the radiation level at an indicator location was significantly larger than that at the control location. The difference would have to be greater than could be accounted for by typical fluctuations in radiation levels arising from other sources.

An additional interpretive technique involves analyses for specific radionuclides present in the environmental samples collected from the Plant site. The Plant's monitoring program includes analyses for tritium and iodine-131. Most samples are also analyzed for gamma-emitting isotopes with results for the following groups quantified: zirconium-95, cesium-137, cerium-144, beryllium-7, and potassium-40. The first three gamma-emitting isotopes were selected as radiological impact indicators because of the different characteristic proportions in which they appear in the fission product mix produced by a nuclear reactor and that produced by a nuclear detonation. Each of the three isotopes is produced in roughly equivalent amounts by a reactor: each constitutes about 10% of the total activity of fission products 10 days after reactor shutdown. On the other hand, 10 days after a nuclear explosion, the contributions of zirconium-95, cerium-144, and cesium-137 to the activity of the resulting debris are in the approximate ratio 4:1:0.03 (Eisenbud, 1963). Beryllium-7 is of cosmogenic origin and potassium-40 is a naturally-occurring isotope. They were chosen as calibration monitors and should not be considered radiological impact indicators.

The other group quantified consists of niobium-95, ruthenium-103, and -106, cesium-134, barium-lanthanum-140, and cerium-141. These isotopes are released in small quantities by nuclear power plants, but to date their major source of injection into the general environment has been atmospheric nuclear testing. Nuclides of the final group, manganese-54, iron-59, cobalt-58, and -60, and zinc-65, are activation products and arise from activation of corrosion products. They are typical components of a nuclear power plant's effluents, but are not produced in significant quantities by nuclear detonations.

Other means of distinguishing sources of environmental radiation can be employed in interpreting the data. Current radiation levels can be compared with previous levels, including those measured before the Plant became operational. Results of the Plant's Monitoring Program can be related to those obtained in other parts of the world. Finally, results can be related to events known to cause elevated levels of radiation in the environment, e.g., atmospheric nuclear detonations.

3.2 Program Description

The sampling and analysis schedule for the environmental radiation monitoring program at Prairie Island is summarized in Table 5.1 and briefly reviewed below. Table 5.2 defines the sampling location codes used in Table 5.1 and specifies for each location its type (indicator or control) and its distance, direction, and sector relative to the reactor site. To assure that sampling is carried out in a reproducible manner, detailed sampling procedures have been prescribed (Hazleton Environmental Sciences Corporation, 1983).

To monitor the air environment, airborne particulates are collected on membrane filters by continuous pumping at five locations. Also, airborne iodine is collected by continuous pumping through charcoal filters at all of these locations. Filters are changed and counted weekly. Particulate filters are analyzed for gross beta activity and charcoal filters for iodine-131. A monthly composite of all particulate filters is gamma-scanned on a Ge or Ge(Li) detector. One of the five locations is a control (P-1), and four are indicator (P-2, P-3, P-4, and P-6). One of the indicators (P-3) is located near the residence expected to be most susceptible to any atmospheric emissions from the Plant (highest X/Q residence).

As a "Lessons Learned" commitment, ambient gamma radiation is monitored at thirty-two (32) locations, using three (3) LiF₂ chips at each location: ten (10) in an inner ring in the general area of the site boundary, fifteen (15) in the outer ring within 4-5 mile radius, six (6) at special interest locations and one control location, 11.1 miles distant from the Plant. They are replaced and measured quarterly. Also, a complete emergency set of TLDs for all locations is placed in the field at the same time as regular sets. The emergency set is returned to TIML quarterly for annealing and repackaging.

Milk samples are collected monthly from five farms (four indicator and one control). All samples are analyzed for iodine-131 and gamma-emitting isotopes. In addition, goat's milk is collected in the vicinity of the Plant, when available, and analyzed for iodine-131.

For additional monitoring of the terrestrial environment, leafy green vegetables (cabbage) are collected annually from a garden nearest the Plant and a control location (P-25) and analyzed for iodine-131. Corn is collected annually from the highest X/Q farm (P-14) and a control location (P-25) and analyzed for gamma-emitting isotopes. Also, well water is collected quarterly and analyzed for tritium and gamma-emitting isotopes.

River water is collected weekly at two locations, one upstream of the Plant (P-5) and one downstream (P-6, Lock and Dam No. 3). Monthly composites are analyzed for gamma-emitting isotopes. Quarterly composites are analyzed for tritium.

Drinking water is collected weekly from the City of Red Wing well. Monthly composites are analyzed for gross beta, iodine-131, and gamma-emitting isotopes. Quarterly composites are analyzed for tritium.

The aquatic environment is also monitored by semi-annual upstream and downstream collections of fish, periphyton or invertebrates, and bottom sediments. Shoreline sediment is collected semi-annually from one location.

3.3 Program Execution

The Program was executed as described in the preceding section with the following exceptions: The TLD data for the third quarter of 1983 for location P-13B and for the fourth quarter of 1983 for location P-03S were not available because they were lost in the field.

3.4 Laboratory Procedures

All iodine-131 analyses in milk were made by using a sensitive radio-chemical procedure which involves separation of the element by use of an ion-exchange resin and subsequent beta counting.

All gamma-spectroscopic analyses were performed with a Ge or Ge(Li) detector. Levels of iodine-131 in cabbage were determined by Ge or Ge(Li) spectrometry. Levels of airborne iodine-131 in charcoal samples were measured by Ge or Ge(Li) spectrometry.

Tritium levels were determined by liquid scintillation technique.

Analytical procedures used by the Teledyne Isotopes Midwest Laboratory are specified in detail elsewhere (Hazleton Environmental Sciences, 1981, presently under revision). Procedures are based on those prescribed by the National Center for Radiological Health of the U. S. Public Health Service (U. S. Public Health Service, 1967) and by the Health and Safety Laboratory of the U. S. Atomic Energy Commission (U. S. Atomic Energy Commission, 1972).

Teledyne Isotopes Midwest Laboratory has a comprehensive quality control/quality assurance program designed to assure the reliability of data obtained. Details of TIML's QA Program are presented elsewhere (Hazleton Environmental Sciences, 1982, presently under revision). The TIML QA Program includes participation in laboratory intercomparison (cross-check) programs. Results obtained in crosscheck programs are presented in Appendix A.

3.5 Program Modifications

Effective January 1, 1983, the following modifications were made in the REMP.

- a. Number of air sampling locations were increased from four to five;
- b. Number of charcoal sampling locations were increased from three to five;
- c. Gamma-isotopic analysis of air particulates was changed from monthly composites from all locations to quarterly composites from each location;
- d. Number of TLD locations was reduced from 36 to 32;
- e. Collection and analysis of natural vegetation, soil, and aquatic vegetation was dropped from the program;
- f. Analysis for strontium-89 and strontium-90 was dropped from the program (all samples);
- g. Lower limit of detection (LLD) for iodine-131 in milk was changed from 0.25 to 1.0 pCi/l;
- h. Analysis for iodine-131 in drinking water was added to the program.

3.6 Land Use Census

In accordance with Technical Specification 4.10, paragraph B1, a land use census shall be conducted and shall identify the location of the nearest milk animal, the nearest residence, and the nearest garden of greater than 500 ft² producing fresh leafy vegetables in each of the 16 meteorological sectors within a distance of 5 miles. This census shall be conducted at least once per 12 months between the dates of May 1 and October 31. New locations shall be added to the radiological environmental monitoring program within 30 days, and sampling locations having lower calculated doses or a lower dose commitment may be deleted from this monitoring program after October 31 of the year in which the land use census was conducted.

This land use census insures the updating of the radiation environmental monitoring program should sampling locations change within the 5 mile radius from the plant.

The 1983 land use census was conducted July 27, 1983 and resulted in changing a dairy farm location from 3.5 miles at 181°/S to another dairy farm located 3.7 miles at 88°/E from the plant. This change occurred October 17, 1983, and is reflected in changes to the map and table identifying the locations of sampling presented in the Offsite Dose Calculation Manual (ODCM). These changes are found in the Semi Annual Radioactive Effluent Release Report submitted to the NRC within 60 days after the end of each 6 month period.

4.0 RESULTS AND DISCUSSION

All collections and analyses were made as scheduled except as listed in Table 5.3.

All results are summarized in Table 5.4 in a format recommended by the Nuclear Regulatory Commission in Regulatory Guide 4.8. For each type of analysis of each sampled medium, this table lists the mean and range for all indicator locations and for all control locations. The locations with the highest mean and range are also shown.

4.1 Atmospheric Nuclear Detonations

There were no reported atmospheric nuclear tests in 1983. The last reported test was conducted by the People's Republic of China on 16 October 1980. The reported yield was in the 200 kiloton to 1 megaton range.

4.2 Program Findings

Program findings show background levels of radioactivity in the environmental samples collected in the vicinity of the Prairie Island Nuclear Generating Plant. No plant effect on the environment was indicated.

Ambient Radiation (TLDs)

Ambient radiation was measured in the general area of site boundary, at outer ring 4 - 5 mi distant from the plant, at special interest areas, and at one control location. The means ranged from 12.4 mR/91 days at inner ring locations to 13.4 mR/91 days at outer ring locations. The mean at special locations was 12.7 mR/91 days and 14.9 mR/91 days at control location. The differences are not statistically significant. The dose rates measured were similar to those observed in 1978 (12.1 and 15.1 mR/91 days, respectively; in 1979 (12.6 and 15.3 mR/91 days, respectively), in 1980 (11.2 and 13.5 mR/91 days, respectively), in 1981 (13.0 and 14.5 mR/91 days, respectively), and in 1982 (12.0 and 13.0 mR/91 days, respectively). No Plant effect on ambient gamma radiation was indicated.

Air Particulates

The average annual gross beta activity in airborne particulates was identical at both indicator and control locations (0.024 pCi/m^3) and was about the same as in 1982 (0.025 pCi/m^3). The highest averages for gross beta were for the month of December and the fourth quarter.

The reason for the elevated activity in December and the fourth quarter is not clear. It probably is attributable to the increased use of wood burning stoves. The spring peak, which usually is observed in April - May (2nd quarter) was not observed in 1983. This peak has been observed almost annually (1976, 1979, and 1980 were also exceptions) for many years (Wilson et al., 1969). The spring peak has been attributed to fallout of nuclides from the stratosphere (Gold et al., 1964).

Two pieces of evidence indicate conclusively that the elevated activity observed during the fourth quarter was not attributable to the Plant. In the first place, elevated activity of similar size occurred simultaneously at both the indicator and control locations. Secondly, an identical pattern was observed at the Monticello Nuclear Generating Plant, about 100 miles distant from the Prairie Island Nuclear Generating Plant (Northern States Power Company, 1984).

Except for beryllium-7, which is produced continuously in the upper atmosphere by cosmic radiation (Arnold and Al-Salih, 1955), all other gamma-emitting isotopes were below their respective LLD levels. None of the activities detected were attributable to the Plant operation.

Airborne Iodine

Airborne iodine-131 results were below the detection limit of 0.07 pCi/m^3 in all samples. Thus, there was no indication of a Plant effect.

Milk

Iodine-131 results were below the detection limit of 1.0 pCi/l in all samples.

Cesium-137 results were below the LLD level of 15 pCi/l in all samples. Cesium-137 is a long-lived component (with a half-life of 30.24 years) of worldwide fallout and is found in the environment in trace quantities.

No other gamma-emitting isotopes, except potassium-40, were detected in any of the milk samples. This is consistent with the finding of the National Center for Radiological Health that most radiocontaminants in feed do not find their way into milk due to the selective metabolism of the cow. The common exceptions are radioisotopes of potassium, cesium, strontium, barium and iodine (National Center for Radiological Health, 1968).

In summary, the milk data for 1983 show no radiological effects of the Plant operation.

Drinking Water

In drinking water from the City of Red Wing well, tritium activity was below the LLD level of 330 pCi/l in all samples. Iodine-131 activity was also below the LLD level at 1.0 pCi/l in all samples. As with the other well water samples, all analyses for gamma-emitting isotopes yielded results below detection limits. Gross beta averaged 8.0 pCi/l and was similar to the levels observed in 1979 (10.5 pCi/l), 1980 (11.8 pCi/l), 1981 (10.7 pCi/l), and 1982 (8.9 pCi/l).

River Water

At the upstream and downstream collection sites, quarterly composite tritium levels were below the LLD level of 330 pCi/l in all samples.

River water was also analyzed for gamma-emitting isotopes. All gamma-emitting isotopes were below their respective detection limits. There was no indication of a Plant effect.

Well Water

At the control well P-25, Kinneman Farm and two indicator wells (P-8, Kinney Store, and P-10, Lock and Dam #3) no tritium was detected above LLD level of 330 pCi/l in any of the analyses. At the remaining indicator well (P-9, Plant Well #2), tritium was detected in one quarterly sample and was 590 pCi/l. The activity was similar to that observed in 1982 (380 - 590 pCi/l).

Gamma-emitting isotope levels were below detection limits in all cases.

Crops

Cabbage samples were collected on August 23 and August 29, 1983, and analyzed for iodine-131. Corn samples were also collected on August 23, 1983, and analyzed for gamma-emitting isotopes. All results, except for potassium-40, were below detection limits. There was no indication of a Plant effect.

Fish

Fish samples were collected in May and September, 1983. The only isotope detected was naturally-occurring potassium-40 and there was no significant difference between upstream and downstream results. There was no indication of a Plant effect.

Aquatic Insects and Periphyton

Aquatic insects (invertebrates) and periphyton were collected on June 6 and September 28, 1983. The samples were analyzed for gamma-emitting isotopes. All gamma-emitting isotopes, except for naturally-occurring potassium-40, were below their respective LLD's. No Plant effect was indicated.

Bottom and Shoreline Sediments

Sediment collections were made on May 23 and November 7, 1983. The samples were analyzed for gamma-emitting isotopes. Cesium-137 was detected in two bottom sediment samples and was 0.067 pCi/g dry weight in indicator sample and 0.117 pCi/g dry weight in upstream (control) sample.

The only other gamma-emitting isotope detected was naturally-occurring potassium-40. No Plant effect was indicated.

5.0 TABLES

Table 5.1 Sample collection and analysis program, 1983.

Prairie Island

| Medium | No. | Locations | Collection Type and Frequency ^b | Analysis Type and Frequency ^c |
|--------------------------------------------------------|-----|----------------------------------------------------------|--------------------------------------------------|------------------------------------------------|
| | | Codes (and Type) ^a | | |
| Ambient radiation (TLDs) | 32 | P-01A - P-10A P-01B - P-15B P-01S - P-06S P-01C | C/Q | Ambient gamma |
| Airborne particulates | 5 | P-1(C), P-2, P-3, P-4, P-6 | C/W | GB, GS (QC of each location) |
| Airborne iodine | 5 | P-1(C), P-2, P-3 P-4, P-6 | C/W | I-131 |
| Milk | 5 | P-16 to P-18, P-25(C), P-14 | G/M | I-131, GS |
| River water | 2 | P-5(C), P-6 | G/W | GS(MC), H-3(QC) |
| Drinking water | 1 | P-11 | G/W | GB(MC), I-131(MC) GS(MC), H-3(QC) |
| Well water | 4 | P-25(C), P-6, P-8, P-9 | G/Q | H-3, GS |
| Edible cultivated crops - leafy green vegetables | 2 | P-25(C), P-24 | G/A | I-131 |

Table 5.1 (continued)

Prairie Island

| Medium | Locations | | Collection Type and Frequency ^b | Analysis Type and Frequency ^c |
|-----------------------------------|-----------|-------------------------------|--------------------------------------------|------------------------------------------|
| | No. | Codes (and Type) ^a | | |
| Edible cultivated crops - corn | 2 | P-25(C), P-14 | G/A | GS |
| Fish (one species edible portion) | 2 | P-5(C), P-6 | G/SA | GS |
| Periphyton or invertebrates | 2 | P-5(C), P-6 | G/SA | GS |
| Bottom sediment | 2 | P-5(C), P-6 | G/SA | GS |
| Shoreline sediment | 1 | P-12 | G/SA | GS |

^aLocation codes are defined in Table 5.2. Control stations are indicated by (C). All other stations are indicators.

^bCollection type is coded as follows: C/ = continuous, G/ = grab. Collection frequency is coded as follows: W = weekly, M = monthly, Q = quarterly, SA = semi-annually, A = annually.

^cAnalysis type is coded as follows: GB = gross beta, GS = gamma spectroscopy, H-3 = tritium, I-131 = iodine 131. Analysis frequency is coded as follows: MC = monthly composite, QC = quarterly composite.

Table 5.2 Sampling locations.

Prairie Island

| Code | Type ^a | Name | Location |
|-------|-------------------|---------------------------------|--------------------|
| P-1 | C | Air Station P-1 | 16.5 mi @ 348°/NNW |
| P-2 | | Air Station P-2 | 0.5 mi @ 294°/WNW |
| P-3 | | Air Station P-3 | 0.8 mi @ 313°/NW |
| P-4 | | Air Station P-4 | 0.4 mi @ 359°/N |
| P-5 | C | Upstream of Plant | 0.6 mi @ 60°/ENE |
| P-6 | | Lock & Dam #3 & Air Station P-6 | 1.6 mi @ 129°/SE |
| P-8 | | Kinney Store | 2.0 mi @ 280°/W |
| P-9 | | Plant Well #2 | 0.3 mi @ 306°/NW |
| P-11 | | City of Red Wing | 7.1 mi @ 135°/SE |
| P-12 | | Recreational Area | 3.4 mi @ 116°/ESE |
| P-14 | | Gustafson Farm | 2.2 mi @ 168°/SSE |
| P-16 | | Johnson Farm | 2.5 mi @ 39°/NE |
| P-17 | | Place Farm | 3.5 mi @ 25°/NNE |
| P-18 | | Birk Farm | 3.5 mi @ 181°/S |
| P-24 | | H. Larson Residence | 1.6 mi @ 287°/WNW |
| P-25 | C | Kinneman Farm | 11.1 mi @ 331°/NNW |
| P-01A | | Property Line | 0.4 mi @ 359°/N |
| P-02A | | Property Line | 0.3 mi @ 19°/NNE |
| P-03A | | Property Line | 0.5 mi @ 183°/S |
| P-04A | | Property Line | 0.4 mi @ 204°/SSW |
| P-05A | | Property Line | 0.4 mi @ 225°/SW |
| P-06A | | Property Line | 0.4 mi @ 249°/WSW |
| P-07A | | Property Line | 0.4 mi @ 268°/W |
| P-08A | | Property Line | 0.4 mi @ 291°/NNW |
| P-09A | | Property Line | 0.7 mi @ 317°/NW |
| P-10A | | Property Line | 0.5 mi @ 333°/NNW |
| P-01B | | Thomas Killian Residence | 4.7 mi @ 355°/N |
| P-02B | | Roy Kinneman Farm | 4.8 mi @ 17°/NNE |
| P-03B | | Wayne Anderson Farm | 4.9 mi @ 46°/NE |
| P-04B | | Nelson Drive (Road) | 4.2 mi @ 61°/ENE |
| P-05B | | County Road E and Coulee | 4.1 mi @ 97°/E |
| P-06B | | William Houschildt Residence | 4.4 mi @ 112°/ESE |
| P-07B | | Red Wing Service Center | 4.7 mi @ 140°/SE |
| P-08B | | David Wnuk Residence | 4.1 mi @ 165°/SSE |
| P-09B | | Highway 19 South | 4.2 mi @ 187°/S |
| P-10B | | Cannondale Farm | 4.9 mi @ 200°/SSW |
| P-11B | | Wallace Weberg Farm | 4.5 mi @ 221°/SW |
| P-12B | | Roy Gergen Farm | 4.5 mi @ 247°/WSW |
| P-13B | | Thomas O'Rourke Farm | 4.4 mi @ 270°/W |
| P-14B | | David J. Anderson Farm | 4.9 mi @ 306°/NW |
| P-15B | | Holst Farms | 4.2 mi @ 347°/NNW |
| P-01S | | Federal Lock & Dam #3 | 1.6 mi @ 129°/SE |
| P-02S | | Charles Suter Residence | 0.5 mi @ 155°/SSE |
| P-03S | | Carl Gustafson Farm | 2.2 mi @ 168°/SSE |
| P-04S | | Richard Burt Residence | 2.0 mi @ 228°/SW |
| P-05S | | Kenney Store | 2.0 mi @ 270°/W |
| P-06S | | Earl Flynn Farm | 2.5 mi @ 299°/WNW |
| P-01C | | Robert Kinnemen Farm | 11.1 mi @ 331°/NNW |

^a "C" denotes control location. All other locations are indicators.

Table 5.3 Missed collections and analyses, 1983. Prairie Island NGP.
All required samples were collected and analyzed as scheduled
except the following:

| Sample | Analysis | Location | Coll. Date or Period | Comments |
|----------------------------------------|-------------------|----------|-------------------------|----------------------|
| Thermoluminescent Dosimeters (TLDs) | Ambient Radiation | P-13B | 3rd Qtr. 1983 | Lost in the field |
| Thermoluminescent Dosimeters (TLDs) | Ambient Radiation | P-03S | 4th Qtr. 1983 | Lost in the field |

Table 5.4

Environmental Radiological Monitoring Program Summary.

Name of facility Prairie Island Nuclear Generating Plant Docket No. 50-282, 50-306
 Location of facility Goodhue, Minnesota Reporting period January-December 1983
 (County, state)

| Sample Type (Units) | Type and Number of Analyses ^a | LLD ^b | Indicator Locations Mean(F) ^c Range ^c | Location with Highest Annual Mean | | Control Locations Mean(F) Range | Number of Non-routine Results ^e |
|--------------------------------------------------------------|------------------------------------------|------------------|-------------------------------------------------------------|-----------------------------------------------------------------------|------------------------------------------------------------|---------------------------------|--------------------------------------------|
| | | | | Location ^d | Mean(F) Range | | |
| TLD (mR/91 days) (Inner Ring, General Area at Site Boundary) | Gamma 40 | 3.0 | 12.4 (40/40) (9.1-15.0) | P-09A, Property Line 0.7 mi @ 317°/NW | 13.2 (4/4) (10.9-15.0) | (See control below) | 0 |
| TLD (mR/91 days) (Outer ring, 4-5 miles distant) | Gamma 59 | 3.0 | 13.4 (59/59) (9.8-17.8) | P-15, Holst Farm 4.2 mi @ 347°/NNW | 15.0 (4/4) (13.3-17.8) | (See control below) | 0 |
| TLD (mR/91 days) (Special Interest Areas) | Gamma 23 | 3.0 | 12.7 (23/23) (8.9-18.1) | P-04S, Near Richard Burt Residence 2.0 mi @ 228°/SW | 14.6 (3/3) (12.3-18.1) | (See control below) | 0 |
| TLD (mR/91 days) (control) | Gamma 4 | 3.0 | None | P-01C-R, Kinneman Farm 11.1 mi @ 331°/NNW | 14.9 (4/4) (12.0-17.0) | 14.9 (4/4) (12.0-17.0) | 0 |
| Airborne Particulates (pCi/m ³) | GB 260 | 0.002 | 0.024 (208/208) | P-4, Station P-4 0.4 mi @ 359°/N P-6, Station P-6 1.6 mi @ 129°/SE | 0.025 (52/52) (0.009-0.078) 0.025 (52/52) (0.007-0.070) | 0.024 (52/52) (0.002-0.070) | 0 |
| | GS 20 | | | | | | |
| | Be-7 | 0.010 | 0.120 (16/16) (0.064-0.174) | P-4, Station P-4 0.4 mi @ 359°/N | 0.129 (4/4) (0.077-0.174) | 0.113 (4/4) (0.089-0.137) | 0 |
| | Mn-54 | 0.0020 | <LLD | - | - | <LLD | 0 |
| | Co-58 | 0.0034 | <LLD | - | - | <LLD | 0 |
| | Co-60 | 0.0023 | <LLD | - | - | <LLD | 0 |
| | Zn-65 | 0.0057 | <LLD | - | - | <LLD | 0 |
| | Nb-95 | 0.0043 | <LLD | - | - | <LLD | 0 |

Table 5.4 (Continued)
Name of Facility Prairie Island Nuclear Generating Plant

| Sample Type (Units) | Type and Number of Analyses ^a | | Indicator Locations Mean(F) ^c Range ^c | Location with Highest Annual Mean | | Control Locations Mean(F) Range | Number of Non-routine Results ^e |
|------------------------------------------------------|------------------------------------------|-----|-------------------------------------------------------------|-----------------------------------|-------------------------------------------|---------------------------------|--------------------------------------------|
| | | | | Location ^d | Mean(F) Range | | |
| Airborne Particulates (pCi/m ³) (cont'd) | Zr-95 | | 0.0065 | <LLD | - | <LLD | 0 |
| | Ru-103 | | 0.0064 | <LLD | - | <LLD | 0 |
| | Ru-106 | | 0.019 | <LLD | - | <LLD | 0 |
| | Cs-134 | | 0.0017 | <LLD | - | <LLD | 0 |
| | Cs-137 | | 0.0019 | <LLD | - | <LLD | 0 |
| | Ba-140 | | 0.0050 | <LLD | - | <LLD | 0 |
| | La-140 | | 0.0074 | <LLD | - | <LLD | 0 |
| | Ce-141 | | 0.0012 | 0.013 (1/4) - | P-4, Station P-4 0.4 mi @ 359°/N - | 0.013 (1/4) - | <LLD 0 |
| | Ce-144 | | 0.0098 | 0.016 (1/4) - | P-3, Station P-3 0.8 mi @ 313°/NW - | 0.016 (1/4) - | <LLD 0 |
| Airborne Iodine (pCi/m ³) | I-131 | 260 | 0.07 | <LLD | - | <LLD | 0 |
| Milk (pCi/l) | I-131 | 64 | 1.0 | <LLD | - | <LLD | 0 |
| | GS | 60 | | | | | |
| | K-40 | | 100 | 1330 (48/48) (1110-1660) | P-16, Johnson Farm 2.5 mi @ 39°/NE | 1350 (12/12) (1140-1560) | 1290 (12/12) (1150-1510) 0 |
| | Cs-134 | | 15 | <LLD | - | <LLD | 0 |
| | Cs-137 | | 15 | <LLD | - | <LLD | 0 |
| | Ba-La-140 | | 15 | <LLD | - | <LLD | 0 |

Table 5.4 (Continued)
Name of facility Prairie Island Nuclear Generating Plant

| Sample Type (Units) | Type and Number of Analyses ^a | LLD ^b | Indicator Locations Mean(F) ^c Range ^c | Location with Highest Annual Mean | | Control Locations Mean(F) Range | Number of Non-routine Results ^e |
|------------------------|------------------------------------------|------------------|-------------------------------------------------------------|-----------------------------------------|------------------------|---------------------------------|--------------------------------------------|
| | | | | Location ^d | Mean(F) Range | | |
| Drinking Water (pCi/l) | GB 12 | 1.0 | 8.0 (12/12) (6.1-10.0) | P-11, City of Red Wing 7.1 mi @ 135°/SE | 8.0 (12/12) (6.1-10.0) | None | 0 |
| | I-131 12 | 1.0 | <LLD | - | - | None | 0 |
| | H-3 4 | 330 | <LLD | - | - | None | 0 |
| | GS 12 | | | | | | |
| | Mn-54 | 15 | <LLD | - | - | None | 0 |
| | Fe-59 | 34 | <LLD | - | - | None | 0 |
| | Co-58 | 15 | <LLD | - | - | None | 0 |
| | Co-60 | 15 | <LLD | - | - | None | 0 |
| | Zn-65 | 30 | <LLD | - | - | None | 0 |
| | Nb-95 | 21 | <LLD | - | - | None | 0 |
| | Zr-95 | 33 | <LLD | - | - | None | 0 |
| | Cs-134 | 10 | <LLD | - | - | None | 0 |
| | Cs-137 | 10 | <LLD | - | - | None | 0 |
| | Ba-La-140 | 16 | <LLD | - | - | None | 0 |
| | Ce-144 | 109 | <LLD | - | - | None | 0 |
| River Water (pCi/l) | H-3 8 | 330 | <LLD | - | - | <LLD | 0 |
| | GS 24 | | | | | | |
| | Mn-54 | 15 | <LLD | - | - | <LLD | 0 |
| | Fe-59 | 49 | <LLD | - | - | <LLD | 0 |
| | Co-58 | 15 | <LLD | - | - | <LLD | 0 |
| | Co-60 | 15 | <LLD | - | - | <LLD | 0 |
| | Zn-65 | 30 | <LLD | - | - | <LLD | 0 |
| | Nb-95 | 28 | <LLD | - | - | <LLD | 0 |

Table 5.4 (Continued)
Name of facility Prairie Island Nuclear Generating Plant

| Sample Type (Units) | Type and Number of Analyses ^a | LLD ^b | Indicator Locations Mean(F) ^c Range ^c | Location with Highest Annual Mean | | Control Locations Mean(F) Range | Number of Non-routine Results ^e |
|------------------------------|------------------------------------------|------------------|-------------------------------------------------------------|-------------------------------------------|------------------------|---------------------------------|--------------------------------------------|
| | | | | Location ^d | Mean(F) Range | | |
| River Water (pCi/l) (Cont'd) | Zr-95 | 30 | <LLD | - | - | <LLD | 0 |
| | Cs-134 | 15 | <LLD | - | - | <LLD | 0 |
| | Cs-137 | 18 | <LLD | - | - | <LLD | 0 |
| | Ba-La-140 | 15 | <LLD | - | - | <LLD | 0 |
| | Ce-144 | 99 | <LLD | - | - | <LLD | 0 |
| Well Water (pCi/l) | H-3 16 | 330 | 590 (1/12) - | P-9 Plant Well #2 0.3 mi @ 306° NW | 590 (1/4) (350-520) | <LLD - | 0 |
| | GS 16 | | | | | | |
| | Mn-54 | 15 | <LLD | - | - | <LLD | 0 |
| | Fe-59 | 30 | <LLD | - | - | <LLD | 0 |
| | Co-58 | 15 | <LLD | - | - | <LLD | 0 |
| | Co-60 | 15 | <LLD | - | - | <LLD | 0 |
| | Zn-65 | 30 | <LLD | - | - | <LLD | 0 |
| | Nb-95 | 15 | <LLD | - | - | <LLD | 0 |
| | Zr-95 | 25 | <LLD | - | - | <LLD | 0 |
| | Cs-134 | 10 | <LLD | - | - | <LLD | 0 |
| | Cs-137 | 10 | <LLD | - | - | <LLD | 0 |
| | Ba-La-140 | 15 | <LLD | - | - | <LLD | 0 |
| | Ce-144 | 108 | <LLD | - | - | <LLD | 0 |
| Crops-Cabbage (pCi/g wet) | I-131 3 | 0.025 | <LLD | - | - | <LLD | 0 |
| Crops-Corn (pCi/l) | GS 2 | | | | | | |
| | Be-7 | 0.31 | <LLD | - | - | <LLD | 0 |
| | K-40 | 0.5 | 2.14 (1/1) - | P-14, Gustafson Farm 2.2 mi @ 168°/SSE | 2.08 (1/1) - | 2.08 (1/1) - | 0 |

Table 5.4 (Continued)
Name of facility Prairie Island Nuclear Generating Plant

| Sample Type (Units) | Type and Number of Analyses ^a | LLD ^b | Indicator Locations Mean(F) ^c Range ^c | Location with Highest Annual Mean | | Control Locations Mean(F) Range | Number of Non-routine Results ^e |
|-----------------------------|------------------------------------------|------------------|-------------------------------------------------------------|---------------------------------------|------------------------|---------------------------------|--------------------------------------------|
| | | | | Location ^d | Mean(F) Range | | |
| Crops-Corn (pCi/l) (Cont'd) | Mn-54 | 0.039 | <LLD | - | - | <LLD | 0 |
| | Co-58 | 0.030 | <LLD | - | - | <LLD | 0 |
| | Co-60 | 0.033 | <LLD | - | - | <LLD | 0 |
| | Zn-65 | 0.097 | <LLD | - | - | <LLD | 0 |
| | Nb-95 | 0.050 | <LLD | - | - | <LLD | 0 |
| | Zr-95 | 0.073 | <LLD | - | - | <LLD | 0 |
| | Ru-103 | 0.040 | <LLD | - | - | <LLD | 0 |
| | Ru-106 | 0.23 | <LLD | - | - | <LLD | 0 |
| | Cs-134 | 0.029 | <LLD | - | - | <LLD | 0 |
| | Cs-137 | 0.030 | <LLD | - | - | <LLD | 0 |
| | Ba-140 | 0.093 | <LLD | - | - | <LLD | 0 |
| | La-140 | 0.026 | <LLD | - | - | <LLD | 0 |
| | Ce-141 | 0.048 | <LLD | - | - | <LLD | 0 |
| | Ce-144 | 0.16 | <LLD | - | - | <LLD | 0 |
| Fish-Flesh (pCi/g wet) | GS 4 | | | | | | |
| | K-40 | 0.1 | 2.88 (2/2) (2.15-3.60) | P-6 Lock & Dam #3 1.6 mi @ 129° SE | 3.23 (4/4) (1.94-3.35) | 2.64 (2/2) (2.44-2.85) | 0 |
| | Mn-54 | 0.032 | <LLD | - | - | <LLD | 0 |
| | Fe-59 | 0.12 | <LLD | - | - | <LLD | 0 |
| | Co-58 | 0.046 | <LLD | - | - | <LLD | 0 |
| | Co-60 | 0.042 | <LLD | - | - | <LLD | 0 |
| | Zn-65 | 0.082 | <LLD | - | - | <LLD | 0 |
| | Nb-95 | 0.097 | <LLD | - | - | <LLD | 0 |
| | Zr-95 | 0.097 | <LLD | - | - | <LLD | 0 |
| | Cs-134 | 0.034 | <LLD | - | - | <LLD | 0 |
| | Cs-137 | 0.036 | <LLD | - | - | <LLD | 0 |
| | Ba-La-140 | 0.088 | <LLD | - | - | <LLD | 0 |

Table 5.4 (Continued)
Name of facility Prairie Island Nuclear Generating Plant

| Sample Type (Units) | Type and Number of Analyses ^a | LLD ^b | Indicator Locations Mean(F) ^c Range ^c | Location with Highest Annual Mean | | Control Locations Mean(F) Range | Number of Non-routine Results ^e |
|---------------------------|------------------------------------------|------------------|-------------------------------------------------------------|--------------------------------------------|---------------|---------------------------------|--------------------------------------------|
| | | | | Location ^d | Mean(F) Range | | |
| Invertebrates (pCi/g wet) | GS 4 | | | | | | |
| | Be-7 | 6.5 | <LLD | - | - | <LLD | 0 |
| | K-40 | 3.4 | 7.24 (1/2) | P-5, Upstream of Plant 0.6 mi @ 60°/ENE | 10.40 (1/2) | 10.40 (1/2) | 0 |
| | Mn-54 | 0.50 | <LLD | - | - | <LLD | 0 |
| | Co-58 | 0.76 | <LLD | - | - | <LLD | 0 |
| | Co-60 | 0.49 | <LLD | - | - | <LLD | 0 |
| | Zn-65 | 1.29 | <LLD | - | - | <LLD | 0 |
| | Nb-95 | 1.23 | <LLD | - | - | <LLD | 0 |
| | Zr-95 | 1.33 | <LLD | - | - | <LLD | 0 |
| | Ru-103 | 0.97 | <LLD | - | - | <LLD | 0 |
| | Ru-106 | 3.91 | <LLD | - | - | <LLD | 0 |
| | Cs-134 | 0.39 | <LLD | - | - | <LLD | 0 |
| | Cs-137 | 0.44 | <LLD | - | - | <LLD | 0 |
| | Ba-140 | 1.36 | <LLD | - | - | <LLD | 0 |
| | La-140 | 0.39 | <LLD | - | - | <LLD | 0 |
| | Ce-141 | 1.58 | <LLD | - | - | <LLD | 0 |
| | Ce-144 | 2.39 | <LLD | - | - | <LLD | 0 |

Table 5.4 (Continued)
Name of facility Prairie Island Nuclear Generating Plant

| Sample Type (Units) | Type and Number of Analyses ^a | LLD ^b | Indicator Locations Mean(F) ^c Range ^c | Location with Highest Annual Mean | | Control Locations Mean(F) Range | Number of Non-routine Results ^e |
|--------------------------------------------|------------------------------------------|------------------|-------------------------------------------------------------|--------------------------------------------|-----------------------------|---------------------------------|--------------------------------------------|
| | | | | Location ^d | Mean(F) Range | | |
| Bottom and Shoreline Sediments (pCi/g dry) | GS 6 | | | | | | |
| | Be-7 | 0.89 | <LLD | - | - | <LLD | 0 |
| | K-40 | 1.0 | 10.48 (2/4) (9.86-11.10) | P-5, Upstream of Plant 0.6 mi @ 60°/ENE | 11.04 (4/4) (9.01-14.00) | 11.04 (4/4) (9.01-14.00) | 0 |
| | Mn-54 | 0.062 | <LLD | - | - | <LLD | 0 |
| | Co-58 | 0.074 | <LLD | - | - | <LLD | 0 |
| | Co-60 | 0.058 | <LLD | - | - | <LLD | 0 |
| | Zn-65 | 0.19 | <LLD | - | - | <LLD | 0 |
| | Nb-65 | 0.13 | <LLD | - | - | <LLD | 0 |
| | Zr-95 | 0.14 | <LLD | - | - | <LLD | 0 |
| | Ru-103 | 0.11 | <LLD | - | - | <LLD | 0 |
| | Ru-106 | 0.59 | <LLD | - | - | <LLD | 0 |
| | Cs-134 | 0.11 | <LLD | - | - | <LLD | 0 |
| | Cs-137 | 0.056 | 0.067 (1/2) - | P-6, Lock & Dam #3 1.6 mi @ 129°/SE | 0.117 (1/4) - | 0.117 (1/4) - | 0 |
| | Ba-La-140 | 0.11 | <LLD | - | - | <LLD | 0 |
| | Ce-141 | 0.14 | <LLD | - | - | <LLD | 0 |
| | Ce-144 | 0.31 | <LLD | - | - | <LLD | 0 |

^a GB = gross beta; GS = gamma scan.

^b LLD = nominal lower limit of detection based on 4.66 sigma error for background sample.

^c Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified location is indicated in parentheses (F).

^d Locations are specified (1) by name and code (Table 2) and (2) distance, direction, and sector relative to reactor site.

^e Nonroutine results are those which exceed ten times the control station value. If no control station value is available, the result is considered nonroutine if it exceeds ten times the preoperational value for the location.

6.0 REFERENCES CITED

- Arnold, J. R. and H. A. Al-Salih. 1955. Beryllium-7 Produced by Cosmic Rays. Science 121: 451-453.
- Eisenbud, M. 1963. Environmental Radioactivity, McGraw-Hill, New York, New York, pp. 213, 275 and 276.
- Gold, S., H. W. Barkhau, B. Shlein, and B. Kahn, 1964. Measurement of Naturally Occurring Radionuclides in Air, in the Natural Radiation Environment, University of Chicago Press, Chicago, Illinois, 369-382.
- Hazleton Environmental Sciences Corporation. 1975. Sampling Procedures, Prairie Island Nuclear Generating Plant, Revision 12, 1 May 1983.
- _____. 1979a. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1978.
- _____. 1979b. Radiation Environmental Monitoring for Monticello Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1978.
- _____. 1980a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1979.
- _____. 1980b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1979.
- _____. 1981a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January-December 1980.
- _____. 1981b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1980.
- _____. 1982a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1981.
- _____. 1982b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1981.
- _____. 1983a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1982.

- _____. 1983b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1982.
- _____. 1982. Quality Assurance Program Manual, Revision 0, 1 January 1982. (Under revision)
- _____. 1977. Analytical Procedures Manual, Nuclear Sciences Section, Revision 3, 22 May 1981. (Under revision)
- National Center for Radiological Health, 1968. Radiological Health and Data Reports, Vol. 9, Number 12, 730-746.
- Northern States Power Company. 1979. Prairie Island Nuclear Generating Plant, Annual Radiation Environmental Monitoring Report to the U.S. Nuclear Regulatory Commission, January 1, 1978 to December 31, 1978 (prepared by Hazleton Environmental Sciences). Minneapolis, Minnesota.
- _____. 1980. Prairie Island Nuclear Generating Plant, Annual Radiation Environmental Monitoring Report to the U.S. Nuclear Regulatory Commission, January 1, 1979 to December 31, 1979 (prepared by Hazleton Environmental Sciences). Minneapolis, Minnesota.
- _____. 1981. Prairie Island Nuclear Generating Plant, Annual Radiation Environmental Monitoring Report to the U.S. Nuclear Regulatory Commission, January 1, 1980 to December 31, 1980 (prepared by Hazleton Environmental Sciences). Minneapolis, Minnesota.
- _____. 1982. Prairie Island Nuclear Generating Plant, Annual Radiation Environmental Monitoring Report to the U.S. Nuclear Regulatory Commission, January 1, 1981 to December 31, 1981 (prepared by Hazleton Environmental Sciences). Minneapolis, Minnesota.
- _____. 1983. Prairie Island Nuclear Generating Plant, Annual Radiation Environmental Monitoring Report to the U.S. Nuclear Regulatory Commission, January 1, 1982 to December 31, 1982 (prepared by Hazleton Environmental Sciences). Minneapolis, Minnesota.
- Teledyne Isotopes Midwest Laboratory. 1971a. Quality Control Program, Revision 6, 15 July 1983.
- _____. 1971b. Quality Control Procedures Manual, Revision 5, 15 July 1983.
- _____. 1984a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1983.
- _____. 1984b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant. Complete Analysis Data Tables, January - December 1983.

- U. S. Atomic Energy Commission. 1972. HASL Procedures Manual, Health and Safety Laboratory, New York, NY., 10014.
- U. S. Public Health Service. 1967. Radioassay Procedures for Environmental Samples, National Center for Radiological Health, Rockville, Maryland (Public Health Service Publication No. 999-RH-27).
- Wilson, D. W., G. M. Ward and J. E. Johnson. 1969. In Environmental Contamination by Radioactive Materials, International Atomic Energy Agency. p. 125.

Appendix A
Crosscheck Program Results

Appendix A

Crosscheck Program Results

Teledyne Isotopes Midwest Laboratory (formerly Hazleton Environmental Sciences) has participated in interlaboratory comparison (crosscheck) programs since the formulation of its quality control program in December 1971. These programs are operated by agencies which supply environmental-type samples (e.g., milk or water) containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on the laboratory's analytical procedures and to alert it to any possible problems.

Participant laboratories measure the concentrations of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

The results in Table A-1 were obtained through participation in the environmental sample crosscheck program for milk and water samples during the period 1980 through 1983. This program has been conducted by the U. S. Environmental Protection Agency Intercomparison and Calibration Section, Quality Assurance Branch, Environmental Monitoring and Support Laboratory, Las Vegas, Nevada.

The results in Table A-2 were obtained for thermoluminescent dosimeters (TLD's) during the period 1976, 1977, 1979, 1980, and 1981 through participation in the Second, Third, Fourth, and Fifth International Intercomparison of Environmental Dosimeters under the sponsorships listed in Table A-2.

Table A-1. U.S. Environmental Protection Agency's crosscheck program, comparison of EPA and Teledyne Isotopes Midwest Laboratory results for milk and water samples, 1980 through 1983^a.

| Lab Code | Sample Type | Date Collected | Analysis | Concentration in pCi/l ^b | |
|----------|-------------|----------------|-------------------------------------------------------|--------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------|
| | | | | TIML Result $\pm 2\sigma^c$ | EPA Result $\pm 3\sigma, n=1^d$ |
| STW-206 | Water | Jan. 1980 | Gross Alpha Gross Beta | 19.0 \pm 2.0 48.0 \pm 2.0 | 30.0 \pm 8.0 45.0 \pm 5.0 |
| STW-208 | Water | Jan. 1980 | Sr-89 Sr-90 | 6.1 \pm 1.2 23.9 \pm 1.1 | 10.0 \pm 0.5 25.5 \pm 1.5 |
| STW-209 | Water | Feb. 1980 | Cr-51 Co-60 Zn-65 Ru-106 Cs-134 Cs-137 | 112 \pm 14 12.7 \pm 2.3 29.7 \pm 2.3 71.7 \pm 1.5 12.0 \pm 2.0 30.0 \pm 2.7 | 101 \pm 5.0 11 \pm 5.0 25 \pm 5.0 51 \pm 5 10 \pm 5.0 30 \pm 5.0 |
| STW-210 | Water | Feb. 1980 | H-3 | 1800 \pm 120 | 1750 \pm 340 |
| STW-211 | Water | March 1980 | Ra-226 Ra-228 | 15.7 \pm 0.2 3.5 \pm 0.3 | 16.0 \pm 2.4 2.6 \pm 0.4 |
| STM-217 | Milk | May 1980 | Sr-89 Sr-90 | 4.4 \pm 2.69 10.0 \pm 1.0 | 5 \pm 5 12 \pm 1.5 |
| STW-221 | Water | June 1980 | Ra-226 Ra-228 | 2.0 \pm 0.0 1.6 \pm 0.1 | 1.7 \pm 0.8 1.7 \pm 0.8 |
| STW-223 | Water | July 1980 | Gross Alpha Gross Beta | 31 \pm 3.0 44 \pm 4 | 38 \pm 5.0 35 \pm 5.0 |
| STW-224 | Water | July 1980 | Cs-137 Ba-140 K-40 I-131 | 33.9 \pm 0.4 <12 1350 \pm 60 <5.0 | 35 \pm 5.0 0 1550 \pm 78 0 |
| STW-225 | Water | Aug. 1980 | H-3 | 1280 \pm 50 | 1210 \pm 329 |
| STW-226 | Water | Sept. 1980 | Sr-89 Sr-90 | 22 \pm 1.2 12 \pm 0.6 | 24 \pm 8.6 15 \pm 2.6 |
| STW-228 | Water | Sept. 1980 | Gross Alpha Gross Beta | NA ^e 22.5 \pm 0.0 | 32.0 \pm 8.0 21.0 \pm 5.0 |
| STW-235 | Water | Dec. 1980 | H-3 | 2420 \pm 30 | 2240 \pm 604 |

Table A-1. (continued)

| Lab Code | Sample Type | Date Collected | Analysis | Concentration in pCi/l ^b | |
|----------|-------------|----------------|-------------|-------------------------------------|---------------------------------------|
| | | | | TIML Result $\pm 2\sigma^c$ | EPA Result $\pm 3\sigma$, $n=1^d$ |
| STW-237 | Water | Jan. 1981 | Sr-89 | 13.0 \pm 1.0 | 16 \pm 8.7 |
| | | | Sr-90 | 24.0 \pm 0.6 | 34 \pm 2.9 |
| STM-239 | Milk | Jan. 1981 | Sr-89 | <210 | 0 |
| | | | Sr-90 | 15.7 \pm 2.6 | 20 \pm 3.0 |
| | | | I-131 | 30.9 \pm 4.8 | 26 \pm 10.0 |
| | | | Cs-137 | 46.9 \pm 2.9 | 43 \pm 9.0 |
| | | | Ba-140 | <21 | 0 |
| | | | K-40 | 1330 \pm 53 | 1550 \pm 134 |
| STW-240 | Water | Jan. 1981 | Gross alpha | 7.3 \pm 2.0 | 9 \pm 5.0 |
| | | | Gross beta | 41.0 \pm 3.1 | 44 \pm 5.0 |
| STW-243 | Water | Mar. 1981 | Ra-226 | 3.5 \pm 0.06 | 3.4 \pm 0.5 |
| | | | Ra-228 | 6.5 \pm 2.3 | 7.3 \pm 1.1 |
| STW-245 | Water | Apr. 1981 | H-3 | 3210 \pm 115 | 2710 \pm 355 |
| STW-249 | Water | May 1981 | Sr-89 | 51 \pm 3.6 | 36 \pm 8.7 |
| | | | Sr-90 | 22.7 \pm 0.6 | 22 \pm 2.6 |
| STW-251 | Water | May 1981 | Gross alpha | 24.0 \pm 5.3 | 21 \pm 5.2 |
| | | | Gross beta | 16.1 \pm 1.9 | 14 \pm 5.0 |
| STW-252 | Water | Jun. 1981 | H-3 | 2140 \pm 95 | 1950 \pm 596 |
| STW-255 | Water | Jul. 1981 | Gross alpha | 20 \pm 1.5 | 22 \pm 9.5 |
| | | | Gross beta | 13.0 \pm 2.0 | 15 \pm 8.7 |
| STW-259 | Water | Sep. 1981 | Sr-89 | 16.1 \pm 1.0 | 23 \pm 5 |
| | | | Sr-90 | 10.3 \pm 0.9 | 11 \pm 1.5 |
| STW-265 | Water | Oct. 1981 | Gross alpha | 71.2 \pm 19.1 | 80 \pm 20 |
| | | | Gross beta | 123.3 \pm 16.6 | 111 \pm 5.6 |
| | | | Sr-89 | 14.9 \pm 2.0 | 21 \pm 5 |
| | | | Sr-90 | 13.1 \pm 1.7 | 14.4 \pm 1.5 |
| | | | Ra-226 | 13.0 \pm 2.0 | 12.7 \pm 1.9 |
| STW-269 | Water | Dec. 1981 | H-3 | 2516 \pm 181 | 2700 \pm 355 |

Table A-1. (continued)

| Lab Code | Sample Type | Date Collected | Analysis | Concentration in pCi/lb | |
|----------|-------------|----------------|-------------|--------------------------------|------------------------------------|
| | | | | TIML Result $\pm 2\sigma^c$ | EPA Result $\pm 3\sigma, n=1^d$ |
| STW-270 | Water | Jan. 1982 | Sr-89 | 24.3 \pm 2.0 | 21.0 \pm 5.0 |
| | | | Sr-90 | 9.4 \pm 0.5 | 12.0 \pm 1.5 |
| STW-273 | Water | Jan. 1982 | I-131 | 8.6 \pm 0.6 | 8.4 \pm 1.5 |
| STW-275 | Water | Feb. 1982 | H-3 | 1580 \pm 147 | 1820 \pm 342 |
| STW-276 | Water | Feb. 1982 | Cr-51 | <61 | 0 |
| | | | Co-60 | 26.0 \pm 3.7 | 20 \pm 5 |
| | | | Zn-65 | <13 | 15 \pm 5 |
| | | | Ru-106 | <46 | 20 \pm 5 |
| | | | Cs-134 | 26.8 \pm 0.7 | 22 \pm 5 |
| | | | Cs-137 | 29.7 \pm 1.4 | 23 \pm 5 |
| STW-277 | Water | Mar. 1982 | Ra-226 | 11.9 \pm 1.9 | 11.6 \pm 1.7 |
| STW-278 | Water | Mar. 1982 | Gross alpha | 15.6 \pm 1.9 | 19 \pm 5 |
| | | | Gross beta | 19.2 \pm 0.4 | 19 \pm 5 |
| STW-280 | Water | Apr. 1982 | H-3 | 2690 \pm 80 | 2860 \pm 360 |
| STW-281 | Water | Apr. 1982 | Gross alpha | 75 \pm 7.9 | 85 \pm 21 |
| | | | Gross beta | 114.1 \pm 5.9 | 106 \pm 5.3 |
| | | | Sr-89 | 17.4 \pm 1.8 | 24 \pm 5 |
| | | | Sr-90 | 10.5 \pm 0.6 | 12 \pm 1.5 |
| | | | Ra-226 | 11.4 \pm 2.0 | 10.9 \pm 1.5 |
| | | | Co-60 | <4.6 | 0 |
| STW-284 | Water | May 1982 | Gross alpha | 31.5 \pm 6.5 | 27.5 \pm 7 |
| | | | Gross beta | 25.9 \pm 3.4 | 29 \pm 5 |
| STW-285 | Water | June 1982 | H-3 | 1970 \pm 1408 | 1830 \pm 340 |
| STW-286 | Water | June 1982 | Ra-226 | 12.6 \pm 1.5 | 13.4 \pm 3.5 |
| | | | Ra-228 | 11.1 \pm 2.5 | 8.7 \pm 2.3 |
| STW-287 | Water | June 1982 | I-131 | 6.5 \pm 0.3 | 4.4 \pm 0.7 |
| STW-290 | Water | Aug. 1982 | H-3 | 3210 \pm 140 | 2890 \pm 619 |
| STW-291 | Water | Aug. 1982 | I-131 | 94.6 \pm 2.5 | 87 \pm 15 |

Table A-1. (continued)

| Lab Code | Sample Type | Date Collected | Analysis | Concentration in pCi/l ^b | |
|----------|-------------|----------------|-------------|-------------------------------------|------------------------------------------------|
| | | | | TIML Result $\pm 2\sigma^c$ | EPA Result $\pm 3\sigma$, n=1 ^d |
| STW-292 | Water | Sept 1982 | Sr-89 | 22.7 \pm 3.8 | 24.5 \pm 8.7 |
| | | | Sr-90 | 10.9 \pm 0.3 | 14.5 \pm 2.6 |
| STW-296 | Water | Oct. 1982 | Co-60 | 20.0 \pm 1.0 | 20 \pm 8.7 |
| | | | Zn-65 | 32.3 \pm 5.1 | 24 \pm 8.7 |
| | | | Cs-134 | 15.3 \pm 1.5 | 19.0 \pm 8.7 |
| | | | Cs-137 | 21.0 \pm 1.7 | 20.0 \pm 8.7 |
| STW-297 | Water | Oct. 1982 | H-3 | 2470 \pm 20 | 2560 \pm 612 |
| STW-298 | Water | Oct. 1982 | Gross alpha | 32 \pm 30 | 55 \pm 24 |
| | | | Gross beta | 81.7 \pm 6.1 | 81 \pm 8.7 |
| | | | Sr-89 | <2 | 0 |
| | | | Sr-90 | 14.1 \pm 0.9 | 17.2 \pm 2.6 |
| | | | Cs-134 | <2 | 1.8 \pm 8.7 |
| | | | Cs-137 | 22.7 \pm 0.6 | 20 \pm 8.7 |
| | | | Ra-226 | 13.6 \pm 0.3 | 12.5 \pm 3.2 |
| | | | Ra-228 | 3.9 \pm 1.0 | 3.6 \pm 0.9 |
| STW-301 | Water | Nov. 1982 | Gross alpha | 12.0 \pm 1.0 | 19.0 \pm 8.7 |
| | | | Gross beta | 34.0 \pm 2.7 | 24.0 \pm 8.7 |
| STW-302 | Water | Dec. 1982 | I-131 | 40.0 \pm 0.0 | 37.0 \pm 10 |
| STW-303 | Water | Dec. 1982 | H-3 | 1940 \pm 20 | 1990 \pm 345 |
| STW-304 | Water | Dec. 1982 | Ra-226 | 11.7 \pm 0.6 | 11.0 \pm 1.7 |
| | | | Ra-228 | <3 | 0 |
| STW-306 | Water | Jan. 1983 | Sr-89 | 20.0 \pm 8.7 | 29.2 \pm 5 |
| | | | Sr-90 | 21.7 \pm 8.4 | 17.2 \pm 1.5 |
| STW-307 | Water | Jan. 1983 | Gross alpha | 29.0 \pm 4.0 ^g | 29.0 \pm 13 |
| | | | Gross beta | 29.3 \pm 0.6 | 31.0 \pm 8.7 |
| STM-309 | Milk | Feb. 1983 | Sr-89 | 35 \pm 2.0 | 37 \pm 8.7 |
| | | | Sr-90 | 13.7 \pm 0.6 | 18 \pm 2.6 |
| | | | I-131 | 55.7 \pm 3.2 | 55 \pm 10.4 |
| | | | Cs-137 | 29 \pm 1.0 | 26 \pm 8.7 |
| | | | Ba-140 | <27 | 0 |
| | | | K-40 | 1637 \pm 5.8 | 1512 \pm 131 |

Table A-1. (continued)

| Lab Code | Sample Type | Date Collected | Analysis | Concentration in pCi/l ^b | |
|----------------------|-------------|----------------|------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|
| | | | | TIML Result $\pm 2\sigma^c$ | EPA Result $\pm 3\sigma$, n=1 ^d |
| STW-310 | Water | Feb. 1983 | H-3 | 2470 \pm 80 | 2560 \pm 612 |
| STW-311 | Water | March 1983 | Ra-226 Ra-228 | 11.9 \pm 1.3 <2.7 | 12.7 \pm 3.3 0 |
| STW-312 | Water | March 1983 | Gross alpha Gross beta | 31.6 \pm 4.59 27.0 \pm 2.0 | 31 \pm 13.4 28 \pm 8.7 |
| STW-313 | Water | April 1983 | H-3 | 3240 \pm 80 | 3330 \pm 627 |
| STW-316 | Water | May 1983 | Gross alpha Gross beta Sr-89 Sr-90 Ra-226 Co-60 Cs-134 Cs-137 | 94 \pm 7 133 \pm 5 19 \pm 1 12 \pm 1 7.9 \pm 0.4 30 \pm 2 27 \pm 2 29 \pm 1 | 64 \pm 19.9 149 \pm 12.4 24 \pm 8.7 13 \pm 2.6 8.5 \pm 2.25 30 \pm 8.7 33 \pm 8.7 27 \pm 8.7 |
| STW-317 | Water | May 1983 | Sr-89 Sr-90 | 59.7 \pm 2.1 33.7 \pm 1.5 | 57 \pm 8.7 38 \pm 3.3 |
| STW-318 ^f | Water | May 1983 | Gross alpha Gross beta | 12.8 \pm 1.5 49.4 \pm 3.9 | 11 \pm 8.7 57 \pm 8.7 |
| STM-320 | Milk | June 1983 | Sr-89 Sr-90 I-131 Cs-137 K | 20 \pm 0 10 \pm 1 30 \pm 1 52 \pm 2 1553 \pm 57 | 25 \pm 8.7 16 \pm 2.6 30 \pm 10.4 47 \pm 8.7 1486 \pm 129 |
| STW-321 | Water | June 1983 | H-3 | 1470 \pm 89 | 1529 \pm 583 |
| STW-322 | Water | June 1983 | Ra-226 Ra-228 | 4.3 \pm 0.2 <2.5 | 4.8 \pm 1.24 0 |
| STW-323 | Water | July 1983 | Gross alpha Gross beta | 3 \pm 1 21 \pm 0 | 7 \pm 8.7 22 \pm 8.7 |
| STW-324 | Water | August 1983 | I-131 | 13.3 \pm 0.6 | 14 \pm 10.4 |

Table A-1. (continued)

| Lab Code | Sample Type | Date Collected | Analysis | Concentration in pCi/l ^b | |
|----------|-------------|----------------|-------------|-------------------------------------|------------------------------------|
| | | | | TIML Result $\pm 2\sigma^c$ | EPA Result $\pm 3\sigma, n=1^d$ |
| STAF-326 | Air filter | August 1983 | Gross beta | 42 \pm 2 | 36 \pm 8.7 |
| | | | Sr-90 | 14 \pm 2 | 10 \pm 2.6 |
| | | | Cs-137 | 19 \pm 1 | 15 \pm 8.7 |
| STW-328 | Water | Sept. 1983 | Gross alpha | 2.3 \pm 0.6 | 5 \pm 8.7 |
| | | | Gross beta | 10.7 \pm 1.2 | 9 \pm 8.7 |
| STW-329 | Water | Sept. 1983 | Ra-226 | 3.0 \pm 0.2 | 3.1 \pm 0.81 |
| | | | Ra-228 | 3.2 \pm 0.7 | 2.0 \pm 0.52 |
| STW-331 | Water | Oct. 1983 | H-3 | 1303 \pm 32 | 1210 \pm 570 |

^a Results obtained by Teledyne Isotopes Midwest Laboratory as a participant in the environmental sample crosscheck program operated by the Intercomparison and Calibration Section, Quality Assurance Branch, Environmental Monitoring and Support Laboratory, U.S. Environmental Protection Agency, (EPA), Las Vegas, Nevada.

^b All results are in pCi/l, except for elemental potassium (K) data which are in mg/l.

^c Unless otherwise indicated, the TIML results given as the mean $\pm 2\sigma$ standard deviations for three determinations.

^d USEPA results are presented as the known values \pm control limits of 3σ for $n=1$.

^e NA = Not analyzed.

^f Analyzed but not reported to the EPA.

^g Results after calculations corrected (error in calculations when reported to EPA).

Table A-2. Crosscheck program results, thermoluminescent dosimeters (TLDs).

| Lab Code | TLD Type | Measurement | Teledyne Result ±2 ^a | mR | |
|------------------------------------------------|------------------------------|---------------------------|---------------------------------------|------------------------|--------------------------------------------------|
| | | | | Known Value | Average ±2 ^d (all participants) |
| 2nd International Intercomparison ^b | | | | | |
| 115-2 ^b | CaF ₂ :Mn Bulb | Gamma-Field | 17.0±1.9 | 17.1 ^c | 16.4±7.7 |
| | | Gamma-Lab | 20.8±4.1 | 21.3 ^c | 18.8±7.6 |
| 3rd International Intercomparison ^e | | | | | |
| 115-3 ^e | CaF ₂ :Mn Bulb | Gamma-Field | 30.7±3.2 | 34.9±4.8 ^f | 31.5±3.0 |
| | | Gamma-Lab | 89.6±6.4 | 91.7±14.6 ^f | 86.2±24.0 |
| 4th International Intercomparison ^g | | | | | |
| 115-4 ^g | CaF ₂ :Mn Bulb | Gamma-Field | 14.1±1.1 | 14.1±1.4 ^f | 16.0±9.0 |
| | | Gamma-Lab (Low) | 9.3±1.3 | 12.2±2.4 ^f | 12.0±7.6 |
| | | Gamma-Lab (High) | 40.4±1.4 | 45.8±9.2 ^f | 43.9±13.2 |
| 5th International Intercomparison ^h | | | | | |
| 115-5A ^h | CaF ₂ :Mn Bulb | Gamma-Field | 31.4±1.8 | 30.0±6.0 ⁱ | 30.2±14.6 |
| | | Gamma-Lab at beginning | 77.4±5.8 | 75.2±7.6 ⁱ | 75.8±40.4 |
| | | Gamma-Lab at the end | 96.6±5.8 | 88.4±8.8 ⁱ | 90.7±31.2 |

Table A-2. (Continued)

| Lab Code | TLD Type | Measurement | mR | | Average $\pm 2\sigma$ ^d (all participants) |
|---------------------|---------------|------------------------|-----------------------------------------------|-----------------------------|----------------------------------------------------------|
| | | | Teledyne Result $\pm 2\sigma$ ^a | Known Value | |
| 115-5B ^h | LiF-100 Chips | Gamma-Field | 30.3 \pm 4.8 | 30.0 \pm 6 ⁱ | 30.2 \pm 14.6 |
| | | Gamma-Lab at beginning | 81.1 \pm 7.4 | 75.2 \pm 7.6 ⁱ | 75.8 \pm 40.4 |
| | | Gamma-Lab at the end | 85.4 \pm 11.7 | 88.4 \pm 8.8 ⁱ | 90.7 \pm 131.2 |

^aLab result given is the mean $\pm 2\sigma$ standard deviations of three determinations.

^bSecond International Intercomparison of Environmental Dosimeters conducted in April of 1976 by the Health and Safety Laboratory (GASL), New York, New York, and the School of Public Health of the University of Texas, Houston, Texas.

^cValue determined by sponsor of the intercomparison using continuously operated pressurized ion chamber.

^dMean $\pm 2\sigma$ standard deviations of results obtained by all laboratories participating in the program.

^eThird International Intercomparison of Environmental Dosimeters conducted in summer of 1977 by Oak Ridge National Laboratory and the School of Public Health of the University of Texas, Houston, Texas.

^fValue $\pm 2\sigma$ standard deviations as determined by sponsor of the intercomparison using continuously operated pressurized ion chamber.

^gFourth International Intercomparison of Environmental Dosimeters conducted in summer of 1979 by the School of Public Health of the University of Texas, Houston, Texas.

^hFifth International Intercomparison of Environmental Dosimeter conducted in fall of 1980 at Idaho Falls, Idaho and sponsored by the School of Public Health of the University of Texas, Houston, Texas and Environmental Measurements Laboratory, New York, New York, U.S. Department of Energy.

ⁱValue determined by sponsor of the intercomparison using continuously operated pressurized ion chamber.

Appendix B
Data Reporting Conventions

Data Reporting Conventions

1.0. All activities are decay corrected to collection time.

2.0. Single Measurements

Each single measurement is reported as follows:

$$x \pm s$$

where x = value of the measurement;

$s = 2$ counting uncertainty (corresponding to the 95% confidence level).

In cases where the activity is found to be below the lower limit of detection L it is reported as

$$<L$$

where L = is the lower limit of detection based on 4.66σ uncertainty for a background sample.

3.0. Duplicate Analyses

3.1. Individual results: $x_1 \pm s_1$
 $x_2 \pm s_2$

Reported result: $x \pm s$

where $x = (1/2) (x_1 + x_2)$

$$s = (1/2) \sqrt{s_1^2 + s_2^2}$$

3.2. Individual results: $<L_1$
 $<L_2$

Reported result: $<L$

where L = lower of L_1 and L_2

3.3. Individual results: $x \pm s$

$<L$

Reported result: $x \pm s$ if $x \leq L$;

$<L$ otherwise

4.0. Computation of Averages and Standard Deviations

- 4.1 Averages and standard deviations listed in the tables are computed from all of the individual measurements over the period averaged; for example, an annual standard deviation would not be the average of quarterly standard deviations. The average \bar{x} and standard deviations of a set of n numbers x_1, x_2, \dots, x_n are defined as follows:

$$\bar{x} = \frac{1}{n} \sum x$$

$$s = \sqrt{\frac{\sum (x - \bar{x})^2}{n-1}}$$

- 4.2 Values below the highest lower limit of detection are not included in the average.
- 4.3 If all of the values in the averaging group are less than the highest LLD, the highest LLD is reported.
- 4.4 If all but one of the values are less than the highest LLD, the single value x and associated two sigma error is reported.
- 4.5. In rounding off, the following rules are followed:
- 4.5.1. If the figure following those to be retained is less than 5, the figure is dropped, and the retained figures are kept unchanged. As an example, 11.443 is rounded off to 11.44.
- 4.5.2 If the figure following those to be retained is greater than 5, the figure is dropped, and the last retained figure is raised by 1. As an example, 11.446 is rounded off to 11.45.
- 4.5.3. If the figure following those to be retained is 5, and if there are no figures other than zeros beyond the five, the figure 5 is dropped, and the last-place figure retained is increased by one if it is an odd number or it is kept unchanged if an even number. As an example, 11.435 is rounded off to 11.44, while 11.425 is rounded off to 11.42.

Appendix C

Maximum Permissible Concentrations
of Radioactivity in Air and Water
Above Background in Unrestricted Areas

Table C-1. Maximum permissible concentrations of radioactivity in air and water above natural background in unrestricted areas.^a

| Air | | | Water | |
|-------------------------|------|--------------------|---------------------------|---------------------------|
| Gross alpha | 3 | pCi/m ³ | Strontium-89 | 3,000 pCi/l |
| Gross beta | 100 | pCi/m ³ | Strontium-90 | 300 pCi/l |
| Iodine-131 ^b | 0.14 | pCi/m ³ | Cesium-137 | 20,000 pCi/l |
| | | | Barium-140 | 20,000 pCi/l |
| | | | Iodine-131 | 300 pCi/l |
| | | | Potassium-40 ^c | 3,000 pCi/l |
| | | | Gross alpha | 30 pCi/l |
| | | | Gross beta | 100 pCi/l |
| | | | Tritium | 3 x 10 ⁶ pCi/l |

^aTaken from Code of Federal Regulations Title 10, Part 20, Table II and appropriate footnotes. Concentrations may be averaged over a period not greater than one year.

^bFrom 10 CFR 20 but adjusted by a factor of 700 to reduce the dose resulting from the air-grass-cow-milk-child pathway.

^cA natural radionuclide.