



**Florida
Power**
CORPORATION

March 16, 1984
3F0384-10

Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street N. W., Suite 2900
Atlanta, GA 30303

SUBJECT: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
I. E. Bulletin 83-08: Electrical Circuit Breakers With an
Undervoltage Trip Feature in Use in Safety-Related Applications
Other Than the Reactor Trip System

Dear Sir:

Florida Power Corporation has reviewed the subject Bulletin and determined that Crystal River Unit 3 does not use the identified Westinghouse or GE-type circuit breakers with the undervoltage trip feature in safety-related systems, other than as reactor trip breakers.

The application of other types of breakers that use an undervoltage trip feature was also investigated. This investigation revealed that other breakers in safety-related applications do not utilize the "integral" undervoltage trip feature. Rather, these breakers utilize an external or separate relay as an undervoltage trip mechanism.

Sincerely,

G. R. Westafer
Manager Nuclear Operations
Licensing and Fuel Management

RHT/ddl

8404060205 840316
PDR ADOCK 05000302
Q PDR

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555