

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER * 400 NORTH OLIVE STREET, L.B. 81 * DALLAS, TEXAS 75201

BILLY R. CLEMENTS
VICE PRESIDENT - NUCLEAR OPERATIONS

April 2, 1984
TXX #4136
File No. 10130

Mr. John T. Collins
Regional Administrator
USNRC Division of Inspection
and Enforcement, Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

Subject: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 and 50-446
RESPONSE TO IE BULLETIN 83-08

Dear Mr. Collins:

The following information is provided as requested by IE Bulletin 83-08 concerning "Electrical Circuit Breakers with an Undervoltage Trip Feature in Use in Safety-Related Applications other Than the Reactor Trip System."

Action 1

Identify applications of W type DB, W type DS, or G.E. type AK-2 circuit breakers with the UV trip feature as discussed in IEB 83-01 or 83-04 in safety-related applications at your facility, other than as RTBs. CP holders and licensees should also identify similar applications of other types of breakers by other manufacturers that use a UV trip feature. If such circuit breakers are used or planned for use, identify the system(s) involved.

Additional Action

Licensees not using circuit breakers with a UVTA in safety-related applications (other than the reactor trip system) shall submit a negative declaration within 90 days of the receipt of this bulletin.

Response

A review of Comanche Peak Steam Electric Station electrical systems determined that no circuit breakers (except those used for reactor trip

8404060271 840402
PDR ADOCK 05000445
G PDR

IE-11
1/0

Mr. John T. Collins
Page 2

purposes) are provided with the "undervoltage trip" feature. Additionally, there are no plans to purchase or install new breakers which use an "undervoltage trip" unit.


The following manhours were expended in response to this bulletin:

1. Staff time to perform review - 42 hours
2. Staff time to prepare documentation - 6 hours

Should you have additional questions concerning this matter, please contact this office.

To the best of my knowledge, information, and belief, the matters set forth herein are true and correct.

Sincerely,



B. R. Clements
Vice President, Nuclear Operations

BRC:msc

Attachment

Original to: U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

The foregoing response has been subscribed and sworn to before me, a
Notary Public in and for Dallas County, on this 2nd day of
April, 1984.

Glenda Benson

Notary Public

My commission expires Feb. 17, 1985.