

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.  
VICE PRESIDENT  
NUCLEAR OPERATIONS

March 19, 1984

Mr. J. P. O'Reilly,  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II, Suite 2900  
101 Marietta Street, N.W.  
Atlanta, GA 30303


Subject: Virgil C. Summer Nuclear Station  
Docket No. 50/395  
Operating License No. NPF-12  
NRC IE Bulletin No. 83-08

Dear Mr. O'Reilly:

South Carolina Electric and Gas Company (SCE&G) has reviewed NRC IE Bulletin No. 83-08, "Electrical Circuit Breakers with an Undervoltage Trip Feature in Use in Safety-Related Applications Other Than the Reactor Trip System." Other than the Reactor Trip Breakers, SCE&G has identified no Westinghouse type DB, Westinghouse type DS or General Electric type AK-2 circuit breakers with the undervoltage trip feature in safety-related applications at the Virgil C. Summer Nuclear Station.

I declare the statements and matters set forth herein are true and correct to the best of my knowledge, information and belief.

Very truly yours,



O. W. Dixon, Jr.

HID/OWD/gj

cc: V. C. Summer	K. E. Nodland
T. C. Nichols, Jr./O. W. Dixon, Jr.	R. A. Stough
E. H. Crews, Jr.	G. Percival
E. C. Roberts	C. W. Heh
W. A. Williams, Jr.	J. B. Knotts
D. A. Nauman	I&E (Washington)
Group Managers	Document Management*
O. S. Bradham	INPO Records Center*
C. A. Price	NPCF
D. A. Lavigne	File
C. L. Ligon (NSRC)	

8404060345 840319  
PDR ADOCK 05000395  
Q PDR

IEH

10