

Docket No. 50-346

License No. NPF-3

Serial No. 1-417

March 22, 1984



RICHARD P. CROUSE
Vice President
Nuclear
(419) 259-5221

Mr. James G. Keppler, Regional Administrator
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

This is in response to IE Bulletin 83-08, dated December 28, 1983, (Log No. 1-893), concerning "Electrical Circuit Breakers with an Undervoltage Trip Feature in Use in Safety-Related Applications Other than the Reactor Trip System".

In accordance with the Bulletin, Toledo Edison has determined that Westinghouse (W) type DB, W type DS, or GE type AK-2 circuit breakers with the UV trip feature as discussed in IE Bulletin 83-01 or 83-04 are not used in safety-related applications other than as reactor trip breakers. Therefore, no further action is required for IE Bulletin 83-08 for Davis-Besse Nuclear Power Station, Unit 1.

Very truly yours,

RPC:DIM:SGW:nlf

cc: DB-1 NRC Resident Inspector


8404090166 840322
PDR ADOCK 05000346
Q PDR

MAR 26 1984


ATOMIC ENERGY ACT OF 1954
SECTION 182a
SUBMITTAL IN RESPONSE
FOR THE
DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1
FACILITY OPERATING LICENSE NPF-3

This letter is submitted in conformance with Atomic Energy Act of 1954, Section 182a, in response to IE Bulletin 83-08 (Log No. 1-893). This deals with the proper operation of circuit breakers with undervoltage trip attachments being used in safety-related applications other than as reactor trip breakers.

By


Vice President, Nuclear

Sworn to and subscribed before me this 22nd day of March, 1984.


Notary Public

NORA LYNN FLOOD
Notary Public, State of Ohio
My Commission Expires Sept. 1, 1987