

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

SHIELDS L. DALTROFF  
VICE PRESIDENT  
ELECTRIC PRODUCTION

(215) 841-5001

April 2, 1984

Docket Nos. 50-277  
50-278

Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555


SUBJECT: 1983 Annual Report on Safety-Relief  
Valve Challenges at Peach Bottom Atomic  
Power Station

Dear Mr. Eisenhut:

This letter represents the 1983 annual report on safety-relief valve challenges for the Peach Bottom Atomic Power Station as required by the TMI Action Plan, NUREG-0737, Item II.K.3.3. The definition of challenges considered in this report is the automatic opening of the primary coolant system safety or relief valves in response to high reactor pressure. During 1983, there were no challenges to the primary coolant system and relief valves on Peach Bottom Units 2 and 3.

Should you have any questions regarding this matter, please do not hesitate to contact us.

Very truly yours,



cc: A. R. Blough, Site Inspector

8404090339 840402  
PDR ADOCK 05000277  
R PDR

A046  
1/0