



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

March 28, 1984

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Potential Defect with Engine
Mounted Fuel Oil Line/Transamerica
Delaval, Inc. [RDC 84(83)]

Dear Mr. Keppler:

Our final report to you dated January 30, 1984, stated that installation of additional tubing supports for engine mounted fuel oil lines was expected to be complete by April 1, 1984, for Unit 1 and June 1, 1984, for Unit 2.

We now expect rework on the fuel oil lines to be complete by July 1, 1984, for both Units subsequent to Transamerica Delaval, Inc. review of discrepancies between design drawings and as-built conditions and proposed rework.

Sincerely,

Murray R. Edelman
Vice President
Nuclear Group

MRE:pab

cc: Mr. M. L. Gildner
NRC Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1000
Atlanta, Georgia 30339

8404090359 840328
FDR ADOCK 05000440
S PDR

MAR 30 1984

IEJ 1/0