

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning October 31, 1983 and lasting through August 15, 1988 the permittee is authorized to discharge from outfall(s) serial numbers(s) 005 Wastewater Treatment Plant

Such discharges shall be limited and monitored by the permittee as specified below:

EFFLUENT CHARACTERISTIC	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)		Other Units (Specify)		Measurement	Sample
	Daily Ave.	Daily Max.	Daily Ave.	Daily Max.	Frequency	Type
Flow-m ³ /Day (MGD)	--	--	--	--	Monthly	Calculated or metered
pH - Standard Units	6.0-9.0	(Not to be averaged)			Quarterly	Grab
Biochemical Oxygen Demand	1.14(2.50)	1.71(3.75)	30 mg/l	45 mg/l	Quarterly	24 hr. comp.
Total Suspended Solids	1.14(2.50)	1.71(3.75)	30 mg/l	45 mg/l	Quarterly	24 hr. comp.
Fecal Coliform colonies/100 ml	--	--	200	400	*Monthly	Grab

*To be taken at the designated measurement frequency during the chlorination season. The chlorination season is April 1 through September 30 of each year. During this period, effluent chlorination is required.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

Sample taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): at the point of discharge to the discharge canal.

8404100148 831107
PDR ADOCK 05000298
P PDR