



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

34 APR 6 11:01  
April 3, 1984

## NUCLEAR PRODUCTION DEPARTMENT

U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File: 0260/L-835.0  
Special Report 84-016/0 - Fire  
Barriers Opened for Planned  
Maintenance Activities  
AECM-84/0201

On March 1, 1984, fire barriers located in U712 Control Room floor module at LA57-L072 were opened for planned maintenance activities. A fire watch was established in accordance with Technical Specification 3.7.7 until the barriers were restored on March 29, 1984

This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) was exceeded. The event had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

L. F. Dale  
Manager of Nuclear Services

EBS/SHH:-g

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

OFFICIAL COPY

IF22

1/0

8404100268 840403  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System