



**Commonwealth Edison**

One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

April 5, 1984

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: LaSalle County Station Unit 1  
Revised Request for Change to  
NPF-11 Technical Specifications  
Regarding Upgrade to Reflect Unit 2  
Technical Specification Changes  
NRC Docket No. 50-373

Reference (a): LaSalle County Station Unit 2 license NPF-18  
dated December 16, 1983

(b): C. W. Schroeder letter to H. R. Denton  
dated January 13, 1984.

(c): C. W. Schroeder letter to H. R. Denton  
dated March 22, 1984.

Dear Mr. Denton:

Reference (c) resubmitted the following change in technical  
specifications for LaSalle County Station Unit 1.

Change request NPF-11/84-02 - Revise Unit 1 Technical Specifications  
to reflect changes incorporated into Unit 2 Technical Specifications.

This change was originally submitted by Reference (b). The NRC  
rejected Reference (b) and requested that Commonwealth Edison Company resubmit  
this request with additional information.

The purpose of this letter is to correct information that was  
provided in the Reference (c) submittal.

Item 30 of Attachment A should be revised to include page 3/4 6-25  
as follows:

30. Table 3.6.3-1. (Pages 3/4 6-24, 25, 26, 27, 28, 32, 34)

- a. (PCIS valves) added # (3.0.4 not applicable) to various valves.
- b. Revised butterfly valve times after first refuel outage. (Also  
some VQ valve times have changed immediately.)
- c. 1CM023B and 2CM024A have been deleted.
- d. 1E12-F099B added.

8404100393 840405  
PDR ADCK 05000373  
PDR

✓3001  
1/0

April 5, 1984

Item 35 of Attachment A should be revised to correct the applicable page number, 7-46 rather than 7-34:

35. Page 3/4 7-46 - deleted calibration requirement for Main Turbine Bypass System and deleted valve position requirement. Also changed applicability to 25% power. Deleted startup test footnote.

Commonwealth Edison Company is notifying the State of Illinois of the change to our request for this amendment by transmittal of a copy of this letter to the designated State official.

If there are any questions concerning this matter please contact this office.

Respectfully,

*P. L. Barnes*

P. L. Barnes  
Nuclear Licensing Administrator

lm

cc: Dr. A. Bournia  
NRC Resident Inspector - LSCS  
G. Wright - State of Illinois

8416N