

TABLE 3.3-9

REMOTE SHUTDOWN MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>READOUT LOCATION</u>	<u>MEASUREMENT RANGE</u>	<u>MINIMUM CHANNELS OPERABLE</u>
1. Wide Range Neutron Flux	1C43 *	0.1 cps-200% power *	1 *
2. Reactor Trip Breaker Indication	Cable Spreading Room	OPEN-CLOSE	1/trip breaker
3. Reactor Coolant Cold Leg Temperature	1C43	212-705°F	1
4. Pressurizer Pressure	1C43	0-4000 psia	1
5. Pressurizer Level	1C43	0-360 inches	1
6. Steam Generator Pressure	1C43	0-1200 psig	1/steam generator
7. Steam Generator Level	1C43	-401 to +63.5 inches	1/steam generator

* The Wide Range Neutron Flux monitors located on the instrumentation cabinets in the Auxiliary Feedwater pump room may be utilized to meet this requirement during periods when the 1C43 instrumentation is inoperable. During the period when these instruments are utilized to meet the above requirement, they will be subject to the surveillance requirements of Table 4.3-6.

B404120273 B40404
PDR ADDCK 05000317
P PDR