



Log # TXX-92103
File # 10110
CP-92-002
Ref. # 10CFR50.55(e)

February 27, 1992

William J. Cahill, Jr.
Group Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 2
DOCKET NO. 50-446
LINEAR INDICATION IN A 150# FLANGE
SDAR: CP-92-002 (FINAL REPORT)

Gentlemen:


On November 27, 1991, TU Electric discovered a linear indication in a 10-inch 150# flange on a vendor-supplied spool in the Auxiliary Feedwater System. Our last report, logged TXX-92036, dated January 24, 1992, stated that the reportability evaluation for this issue would be completed by February 27, 1992.

The evaluation has now concluded that the indication found in the flange would not propagate or cause a fracture to occur during design operating or testing conditions. Therefore, no substantial safety hazard exists and this issue is not reportable pursuant to 10CFR50.55(e) and 10CFR21.

The deficient flange has been replaced via the corrective action process. Records documenting this evaluation are available onsite for NRC review.

Sincerely,

William J. Cahill, Jr.


By: D. R. Woodlan
Docket Licensing Manager

JTC/tg

c - Mr. R. D. Martin, Region IV
Mr. M. B. Fields, NRR
Resident Inspectors, CPSES (2)

020135

9203020200 920227
PDR ADDCK 05000446
S PDR

00 N. Olive Street L.B. 81 Dallas, Texas 75201

TE27 1/1

ALL

W. G. Council 19BT
 W. M. Taylor/ 31ST
 J. F. Streeter
 W. J. Cahill E22

R. D. Walker/ 24ST
 J. S. Marshall

R. A. Wooldridge 32BT
 R. M. Fillmore 32BT
 J. L. French RT1
 R. L. Ramsey 16BT

H. C. Schmidt 24ST

CCS - E06

J.T. Conly

BY SUBJECT

H. D. Bruner E21

T. E. Redican
 (NODIL) C07A

C. L. Terry E01
 J. W. Muffett C07B

~~A. Husain 24ST~~
~~R. D. Calder C29~~

A. B. Scott E01
~~J. J. Kelley 009~~
~~P. B. Stevens 006~~
~~J. F. McMahon T01~~
~~D. Buschbaum 006~~

D. R. Woodlan 24ST
 R. P. Baker A09
 T. A. Hope C07
 C. W. Rau

M. R. Blevins A08

DISTRIBUTED BY MRB

D. M. McAfee/ A08

R. C. Byrd
 W. G. Guldemon
 (ISEG) A08

~~D. L. Davis (IOER) A08~~

~~J. D. Edwards 24ST~~

DOCKETED

J. Ellis (CASE) (FC)
 J. C. Hicks TB01
 J. L. Vota (FC)
 N. S. Reynolds (FC)
 F. Johnson (FC)

SDAR

C. B. Corbin ST24
 INPO (FC)
 G. Bynod (FC)

CPSES IR & RESPONSES

~~J. Audas C21~~
~~J. Smith 011~~
~~O. Maynard (IRs Only) (FC)~~
~~D. Powell (IRs Only) (FC)~~
~~R. L. Spence C32~~

TXF File (Corp.) 24 ST
 TXF File (Site) A09

OTHER

S. S. Palmer E24
 (ORC or Stipulation Related)

VENDOR

~~S. D. Mann - F04~~

(FC) - First Class Mail

NODIL - Correspondence related to material/component acceptability.

IOER - Correspondence which pertains to IOER program (e.g., generic letters, NRC information notices, NRC bulletins, etc.) and CPSES Inspection Reports.

CASE - All filings and correspondence between the NRC staff and TU Electric.

ORC - All SDAR's, LER's, CPSES Inspection Reports and responses, NRC Bulletins and responses and Generic Letters and responses, description letters for changes to licensing bases documents and license amendments.

ISEG - All IOER material plus inspection reports for TU Electric and other plants.

VENDOR - Vendor documents per STA-206 (Vendor Document Group or VETIP Coordinator)

February 10, 1992