

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
H. B. Robinson, Unit No. 2DOCKET NUMBER (2)
0 5 0 0 0 2 6 1 1 OF 0 2

TITLE (4)

Quarterly Fish Samples

| EVENT DATE (5) | | | LER NUMBER (6) | | | REPORT DATE (7) | | | OTHER FACILITIES INVOLVED (8) | | | | | | | | | | | | |
|----------------|-----|------|----------------|-------------------|-----------------|-----------------|-----|------|-------------------------------|------------------|---|---|---|---|---|---|---|---|---|---|---|
| MONTH | DAY | YEAR | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | MONTH | DAY | YEAR | FACILITY NAMES | DOCKET NUMBER(S) | | | | | | | | | | | |
| 0 | 6 | 0 | 8 | 4 | 0 | 0 | 4 | 0 | 0 | 0 | 7 | 0 | 6 | 8 | 4 | 0 | 5 | 0 | 0 | 0 | 0 |

| OPERATING MODE (9) | THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11) | | | | | | | | | |
|-----------------------------|--|------------------|---------------------|--|--|--|--|--|--|--|
| POWER LEVEL (10) 0 1 0 0 | 20.402(b) | 20.405(e) | 80.73(a)(2)(iv) | 73.71(b) | | | | | | |
| | 20.405(a)(1)(i) | 80.38(a)(1) | 80.73(a)(2)(v) | 73.71(a) | | | | | | |
| | 20.405(a)(1)(ii) | 80.38(a)(2) | 80.73(a)(2)(vi) | OTHER (Specify in Abstract below and in Text, NRC Form 365A) | | | | | | |
| | 20.405(a)(1)(iii) | X 80.73(a)(2)(i) | 80.73(a)(2)(vii)(A) | | | | | | | |
| | 20.405(a)(1)(iv) | 80.73(a)(2)(ii) | 80.73(a)(2)(vii)(B) | | | | | | | |
| 20.405(a)(1)(v) | 80.73(a)(2)(iii) | 80.73(a)(2)(ix) | | | | | | | | |

LICENSEE CONTACT FOR THIS LER (12)

| NAME | TELEPHONE NUMBER |
|------------------|---------------------------------------|
| Carson L. Wright | AREA CODE 8 1 0 3 3 8 1 3 1 4 5 1 2 4 |

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

| CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NRC | CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NRC |
|-------|--------|-----------|--------------|-------------------|-------|--------|-----------|--------------|-------------------|
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

SUPPLEMENTAL REPORT EXPECTED (14)

| YES (If yes, complete EXPECTED SUBMISSION DATE) | NO | EXPECTED SUBMISSION DATE (15) | MONTH | DAY | YEAR |
|---|----|-------------------------------|-------|-----|------|
| | X | | | | |

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On June 6, 1984, it was identified that the second quarter fish samples described in Technical Specification (TS) Table 4.10.1, Item C.3, were not taken within the allowed interval. The fish samples were subsequently taken within the second calendar quarter; however, they were beyond 92 days $\pm 25\%$ from the previous sample. The sampling frequency was misunderstood by the personnel involved to be semi-annual as will be required by the soon to be approved Radiological and Environmental Technical Specification (RETS) amendment.

8407120220 840706
PDR ADOCK 05000262
S PDRIE22
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

| FACILITY NAME (1) | DOCKET NUMBER (2) | LER NUMBER (6) | | | PAGE (3) | | |
|----------------------------|-------------------|----------------|-------------------|-----------------|----------|----|----|
| | | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | | | |
| | | | | | | | |
| H. B. Robinson, Unit No. 2 | 05000261 | 84 | 004 | 00 | 02 | OF | 02 |

TEXT (If more space is required, use additional NRC Form 365A's) (17)

On June 6, 1984, it was identified that the quarterly fish samples for the second quarter described in Technical Specifications (TS) Table 4.10-1, Item C.3 were not taken in the allowed time interval.

These samples were subsequently taken in the second quarter; however, the interval between the quarterly sampling was beyond 92 days $\pm 25\%$ from the previous sample.

The soon to be approved Radiological Environmental Technical Specification (RETS) amendment will change the sampling frequency from quarterly to semi-annual. This contributed to a misunderstanding with offsite personnel who perform the sampling that the semi-annual sampling frequency was already in effect.

This test was tracked by the TS Surveillance Tracking Program; however, sufficient documentation was not reviewed to ensure that the test had been performed. This was complicated by the fact that the testing is done by an offsite group.

Recent revisions have been made to the TS Surveillance Scheduling and Tracking Procedure that should prevent recurrence of this problem.



Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT
Post Office Box 790
Hartsville, South Carolina 29550

JUL 6 1984

Robinson File No: 13510C

Serial: RSEP/84-467

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
LICENSEE EVENT REPORT 84-004

Dear Sir:

In accordance with 10CFR50.73, Licensee Event Report, the enclosed Licensee Event Report is submitted. This report fulfills the requirements for a written report within thirty (30) days of a reportable event and is in accordance with the format set forth in NUREG-1022, September, 1983.

Very truly yours,

R. E. Morgan
General Manager
H. B. Robinson SEG Plant

CLW/sr

Enclosure

cc: J. P. O'Reilly
NRC Resident Inspector's Office
INPO

IE22
1/1