

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 666-6911

June 28, 1984

Docket No. 50-336
B11240

Mr. Darrel G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

- References: (1) W. G. Counsil letter to D. G. Eisenhut, dated December 30, 1983.
- (2) R. W. Wells letter to D. G. Eisenhut, dated May 8, 1984.
- (3) R. W. Wells letter to D. G. Eisenhut, dated February 28, 1984.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2
NUREG-0737 Item ILK.3.5, Automatic Trip of Reactor Coolant Pumps

Northeast Nuclear Energy Company (NNECO) on behalf of Millstone Unit No. 2, informed the NRC Staff in Reference (1) that revised Emergency Procedure Guidelines (EPG) incorporating the strategy for reactor coolant pump trip were scheduled to be submitted in April, 1984. These guidelines have been developed by the Combustion Engineering Owner's Group and were forwarded to the Staff in Reference (2). The guidelines are based on the work presented in CEN-268 which was docketed in Reference (3).


NNECO has reviewed CEN-268 and has determined that it is applicable to Millstone Unit No. 2 for Item ILK.3.5 of NUREG-0737.

NNECO also informed the Staff in Reference (1) that tentative completion dates for operator training and Emergency Operating Procedure (EOP) revisions (based on the revised EPGs) would be provided on or about May 1, 1984. It is NNECO's intention to submit a schedule for EOP revision and operator training following receipt of the NRC Staff Safety Evaluation Report on CEN-268 and Revision 2 of CEN-152.

This will optimize our resources in that pertinent Staff findings will be available from the technical review performed to support the SER which can be factored in to the EOP revision and operator training program.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, reading "W. G. Council", written over a horizontal line.

W. G. Council
Senior Vice President