

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Washington Nuclear Plant - Unit 2DOCKET NUMBER (2)
0 5 0 0 0 3 9 7 1 OF 0 2TITLE (4)
Breach of Fire BarrierEVENT DATE (8)
MONTH DAY YEAR
0 6 1 4 8 4 8 4
LER NUMBER (6)
SEQUENTIAL NUMBER REVISION NUMBER
0 6 1
REPORT DATE (7)
MONTH DAY YEAR
0 7 0 6 8 4
OTHER FACILITIES INVOLVED (8)
FACILITY NAMES DOCKET NUMBER(S)
0 5 0 0 0 0OPERATING MODE (9)
1
POWER LEVEL (10)
0 1 0
THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)
20.402(b) 20.405(a)(1)(i) 20.405(a)(1)(ii) 20.405(a)(1)(iii) 20.405(a)(1)(iv) 20.405(a)(1)(v) 20.405(c) 50.36(e)(1) 50.36(e)(2) 50.73(e)(2)(i) 50.73(e)(2)(ii) 50.73(e)(2)(iii) 50.73(e)(2)(iv) 50.73(e)(2)(v) 50.73(e)(2)(vi) 50.73(e)(2)(vii) 50.73(e)(2)(viii)(A) 50.73(e)(2)(viii)(B) 50.73(e)(2)(ix) 73.71(b) 73.71(c) OTHER (Specify in Abstract below and in Text: NRC Form 356A)LICENSEE CONTACT FOR THIS LER (12)
NAME
C.M. Powers, Reactor Engineering Supervisor
TELEPHONE NUMBER
5 0 9 3 7 7 1 - 1 2 5 0 1 1
AREA CODE
5 0 9 3 7 7 1 - 1 2 5 0 1 1COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)
Ext. 2996
CAUSE SYSTEM COMPONENT MANUFACTURER REPORTABLE TO NPDs
B K P S E A L B 5 7 1 0 NOSUPPLEMENTAL REPORT EXPECTED (14)
X YES (If yes, complete EXPECTED SUBMISSION DATE)
NO
EXPECTED SUBMISSION DATE (15)
MONTH DAY YEAR
0 8 0 1 8 4

ABSTRACT (Limit to 400 spaces - a space is every fifteen single-space typewritten lines) (16)

Floor drain in room R-410 on 522' level of the Reactor Bldg. is open to 501' level. This condition violated the fire barrier separating the room from other fire zones in the Reactor Building. Technical Specification 3.7.7, Fire Rated Assemblies, requires an hourly fire watch to be implemented as compensatory action. Upon discovery of the breach of the fire barrier the required fire patrol was established.

8407120328 840706
PDR ADDOCK 05000397
S PDRIE 22
111

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
Washington Nuclear Plant - Unit 2	0 5 0 0 0 3 9 7 8 4 -	0 6 1 -	0 0 0 2	OF	0 2	

TEXT (If more space is required, use additional NRC Form 388A's) (17)

- (a) Power Level - 10%
(b) Plant Mode - 1
(c) During the Power Ascension Test Program

Event

On 6-14-84 an entry was made into room R-410 on the 522' level of the Reactor Building. This entry was made to verify the earlier findings which identified that the floor drain was not completed in this room. It was found that by looking into the 3" drain, the 501' level of the Reactor Building was visible. This floor is a fire rated assembly and therefore the fire barrier was violated.

Immediate Corrective Action

The Control Room Shift Manager was notified and a fire watch was initiated per Technical Specification 3.7.7.

Future Corrective Action

After an engineering review it was determined that there was to be no drain installed in this room. Engineering direction is being issued to seal this drain with concrete. Ongoing inspection will continue to determine if this condition exists in other areas of the Reactor Building. A later update will document final corrective action.

Safety Significance

In the event of a fire on either side of the fire rated assembly the fire could have been transmitted through the assembly, in less than the rated 3 hours, however, there was no fire and no threat to the ability to safely shutdown the Reactor or to the public existed.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

July 6, 1984


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 84-061

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-061 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

Very truly yours,


J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:mm

Enclosure:
Licensee Event Report No. 84-061

cc: Mr. John B. Martin, Administrator
Region V, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
1450 Maria Lane
Walnut Creek, California 94596
Mr. A. D. Toth, NRC Resident Inspector (901A)
Ms. Dottie Sherman
American Nuclear Insurers
The Exchange Suite 245
270 Farmington Ave.
Farmington, CT 06032

IE22
1/1