



**Entergy  
Operations**

Entergy Operations, Inc.

Plant 2, Box 1313

Rocky Hill, AR 72901

Te 501-904-2500

February 21, 1992

2CAN029203

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2  
Docket No. 50-368  
License No. NFP-6  
Annual Diesel Generator Data Report - 1991


Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specification 6.9.1.5.d requires an annual submittal of a diesel generator data report for the previous calendar year. This report provides the number of valid tests and the number of valid failures for each diesel generator. The purpose of this letter is to provide this information for 1991.

Thirty one (31) valid tests were performed on each diesel generator (2K-4A and 2K-4B) during the reporting period. One (1) valid failure occurred for each diesel generator during 1991.

This letter completes the reporting requirements for Technical Specification 6.9.1.5.d. Should you have any questions regarding this submittal, please contact me.

Very truly yours,

  
James V. Fisicaro  
Director, Licensing

JJF/RWC/sjf

020014

9203030359 920221  
PDR ADOCK 05000368  
R PDR

ADD 1/0

U. S. NRC  
February 21, 1992  
Page 2

cc: Mr. Robert Martin  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

NRC Senior Resident Inspector  
Arkansas Nuclear One - ANO-1 & 2  
Number 1, Nuclear Plant Road  
Russellville, AR 72801

Mr. Thomas W. Alexion  
NRR Project Manager, Ref 7 IV/ANO-1  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-H-3  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852

Ms. Sheri Peterson  
NRR Project Manager, Region IV/ANO-2  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-H-3  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852