



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 713 838-6631

July 5, 1984


RBG-18159

File Nos. G9.5, G9.25.1.1

Mr. John T. Collins, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV, Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Dear Mr. Collins:

River Bend Station Unit 1
Docket No. 50-458
Interim Report/DR-203



An interim or final status report concerning arc strikes on the interior surface of seven of the eight air start receiver tanks on the Standby Diesel Generator supplied by Transamerica Delaval, Incorporated will be provided by October 5, 1984.

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB/PJD/lp

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site