



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72202 (501) 377-4000

April 1, 1988

0CAN048804

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

ATTN: Mr. Robert D. Martin, Administrator

SUBJECT: Arkansas Nuclear One - Units 1 & 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51 and NPF-6
NRC Bulletin 88-01 Defects in Westinghouse
Circuit Breakers TACS 65955/65956

Gentlemen:

In accordance with the actions requested in NRC Bulletin 88-01 (0CNA028805) the Arkansas Power and Light Company (AP&L) performed a review of our equipment history data base for any Class 1E (Safety Related) applications of Westinghouse Series DS circuit breakers.

That review did not identify any instances of these circuit breakers having been installed in Safety Related applications in either Unit 1 or Unit 2. AP&L has concluded based upon this effort that we do not have a safety concern relating to the use of Westinghouse Series DS circuit breakers in Class 1E applications at Arkansas Nuclear One.

Very truly yours,

Dan R. Howard
Manager, Licensing

DRH:MT:mb

050006
9203040292 880401
PDR ADOCK 05000313
Q PDR

MEMBER MIDDLE SOUTH UTILITIES SYSTEM

APR 14 1988

ADD: Daniels Pudinot 1462

L.H.

DF01