


# SAXTON NUCLEAR EXPERIMENTAL CORPORATION

## GENERAL PUBLIC UTILITIES SYSTEM



Jersey Central Power & Light Company  
Pennsylvania Electric Company  
Metropolitan Edison Company

MAILING ADDRESS:

1 Upper Pond Road  
Parsippany, NJ 07054

February 25, 1992  
C301-92-0004  
SNEC-92 0006

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Dear Sir:

Saxton Nuclear Facility  
Operating License No. DPR-4  
Docket No. 50-146  
Fourth Quarter 1991 Containment Vessel Sump Results

On December 5, 1991, the fourth quarterly inspection of the year was conducted at the Saxton Nuclear Experimental Corporation (SNEC) facility. During this inspection, water was found present in the Containment Vessel (CV) sump and a sample was taken for radioisotopic analysis.

The results of the analysis were received on February 20, 1992 and indicated that the activity concentration of Sr-90 and Cs-137 exceeded the "Limits for Unrestricted Release" identified in 10 CFR 20, Appendix B, Table II, Column 2, and is reportable under Section 5.a.3 of the SNEC Technical Specification (TS).

The attached Exhibit 1 identifies the reportable results of the SNEC CV sump water analysis for the fourth quarter of 1991.

It should be noted that the CV sump volume is 325 gallons and was filled with approximately 172 gallons of water.

30192004.1et

9203040331 920225  
PDR ADOCK 05000146  
R PDR


N 5224 (11-88)

The water in the sump originates from condensation on the inside of the CV, and is a consequence of a breather pipe, installed during the initial decommissioning, which permits the CV to breathe with changes in atmospheric temperatures. This water poses no threat to the environment or to the health and safety of the public because there are no release paths to the external environment from the CV sump. When appropriate, the water will be properly disposed of, as it has been in the past.

We will continue to periodically monitor, remove and take the appropriate steps to secure and dispose of this water.

This letter comprises the required written report per the SNEC TS Section 5.a.

Sincerely,



J. E. Hildebrand  
President

JEH/EP/plp  
Attachment

c: A. Adams (NRC)  
R. Bores (NRC)  
T. Dragoun (NRC)  
J. Roth (NRC)  
S. Weiss (NRC)

EXHIBIT 1  
RESULTS OF SNEC CV SUMP WATER  
FOURTH QUARTER, 1991

| <u>Isotope</u> | <u>Concentration (uCi/ml)</u> | 10 CFR 20, App. B*                  |
|----------------|-------------------------------|-------------------------------------|
|                |                               | Table II, Col. 2 Limits<br>(uCi/ml) |
| Cs-137         | $3.01 \pm 0.30 \text{ E-3}$   | 2 E-5 (s)                           |
| Sr-90          | $6.8 \pm 0.1 \text{ E-6}$     | 3 E-7 (s)                           |

\*Values listed are the more restrictive between soluble (s) and insoluble (I).