

CONTROL BLOCK:

--	--	--	--	--	--

LICENSE NAME
01 N Y N M P 1
7 8 9 14

LICENSE NUMBER
15 25

LICENSE TYPE
4 1 1 1 1
26 30

EVENT TYPE
0 4
31 32

CATEGORY
01 CON'T M I
7 8 57 58

REPORT TYPE
T
59

REPORT SOURCE
L
60

DOCKET NUMBER
0 5 0 - 0 2 2 0
61 68

EVENT DATE
0 4 2 8 7 6
69 74

REPORT DATE
0 5 0 4 7 6
75 80

02	During routine impingement sampling by contractor personnel (4/28-29/76) it was	
7	8	9
03	found that the numbers of fish being impinged on the traveling screens exceeded	80
7	8	9
04	the ETS limit of 20,000/24 hr. period as per Sect. 3.1.2.a2	80
7	8	9
05	(See Attachment)	80
7	8	9
06		80
7	8	9
		RO 76-17

SYSTEM CODE: 07 H F
 CAUSE CODE: F
 COMPONENT CODE: Z Z Z Z Z Z
 PRIME COMPONENT SUPPLIER: Z
 COMPONENT MANUFACTURER: Z 9 9 9
 VIOLATION: -

08	There was no apparent cause for this occurrence that could be directly related to	
7 8 9		
09	changes in plant operations. The principal species impinged, alewives, rainbow	80
7 8 9		
10	smelt migrate inshore annually at this time of year.	80
7 8 9		

11	FACILITY STATUS F	% POWER 0 8 7	OTHER STATUS N/A	METHOD OF DISCOVERY a	DISCOVERY DESCRIPTION	80
7 8	9	10 12	13 44	45 46		80
FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE			
12	z	z	N/A	N/A		
7 8	9	10 11	44	45		80
PERSONNEL EXPOSURES						

NUMBER				TYPE	DESCRIPTION
13	0	0	0	2	N/A

NUMBER				DESCRIPTION	
1	4	0	0	0	N/A

1	5	NONE
7	8	9

TYPE				DESCRIPTION
16	2			N/A

17	PUBLICITY	8302170486 760504 PDR ADOCK 05000220 S PDR	80
----	-----------	--	----

18 Contractor personnel remained on Site until numbers fell below 20,000/24 hr. as

per ETS. This occurred on 5/01/76.

NAME: M. Hedrick

343-2110 Ext. 1310

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

May 7, 1976

Mr. James P. O'Reilly
Directorate of Regulatory Operations
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pa. 29406

RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1
Environmental Technical Specification 5.6.3.1, we hereby submit
Licensee Event Report 76-17.

This report was completed within the intent of the Licensee
Event Report Instruction Booklet OOE-SS-001, dated October 1974, re-
vised December 24, 1974. Due to the minimal significance category
of the report, no supplemental report is included.

Very truly yours,

Original Signed by R.R. Schneider

R.R. Schneider
Vice President
Electric Operations

MCH/aih

Enc. 2 copies

cc: (20 copies) Director, Office of Inspection
and Enforcement

(2 copies) Director, Office of Management Information
and Program Control

