

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME: 01 N Y N M P 1 14 15 25 26 4 1 1 1 1 30 31 0 4 32

CATEGORY: 01 CON'T 57 M 58 I 59 T 60 L 61 0 5 0 0 2 2 0 68 69 0 4 2 4 7 6 74 0 4 2 6 7 6 80

EVENT DESCRIPTION

02 7 8 9 During routine surveillance of fish impingement by offsite contractor personnel on 80

03 7 8 9 4/23/76 it was found that impingement numbers were increasing and would exceed ETS 80

04 7 8 9 limit of 20,000/hr. period. This limit was exceeded on 4/24-25/76. (ETS-Sect. 3.1.2.a2) 80

05 7 8 9 04/24/76 - 80,156 (96% alewives) - 04/25/76 - 67,328 (97% alewives) RO 76-15 80

06 7 8 9 80

SYSTEM CODE: 07 7 8 9 10 H F 11 F 12 Z Z Z Z Z Z 17 43 Z 44 Z 9 9 9 47 48 -

CAUSE DESCRIPTION

08 7 8 9 There was no apparent cause for this occurrence related to changes in plant 80

09 7 8 9 operation. The principle species impinged, alewives and smelt migrate inshore 80

10 7 8 9 for spawning annually at this time of year. 80

FACILITY STATUS: 11 7 8 9 10 F 11 0 6 9 12 N/A 13 44 a 45 N/A 46 80

FORM OF ACTIVITY RELEASED: 12 7 8 9 10 Z 11 Z 12 N/A 13 44 N/A 45 80

PERSONNEL EXPOSURES

13 7 8 9 10 0 0 0 11 Z 12 N/A 13 80

PERSONNEL INJURIES

14 7 8 9 10 0 0 0 11 N/A 12 80

RESULTS & CONSEQUENCES Probable

15 7 8 9 NONE 80

LOSS OR DAMAGE TO FACILITY

16 7 8 9 10 Z 11 N/A 12 80

PUBLICITY: 17 7 8 9 10 N/A 11 S 12 80

ADDITIONAL FACTORS

18 7 8 9 Contractor personnel remained on site to monitor impingement until numbers fell 80

19 7 8 9 below 20,000/24 hr. as per ETS. 80