

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME														LICENSE NUMBER										LICENSE TYPE					EVENT TYPE	
01	N	Y	N	M	P	1								4	1	1	1	1	0	1										
7	8	9				14	15							25	26				30	31	32									

CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER						EVENT DATE				REPORT DATE									
01	CON'T	M	1	L	L	0	5	0		0	2	1	0	0	2	0	4	7	6	0	3	0	3	7	6
7	8	57	58	59	60	61							68	69				74	75				80		

EVENT DESCRIPTION

02 | Following a review it was discovered that the KW/FT vs Exposure curve points for 80

03 | MAPHLGR placed in the process computer for Type 5 Fuel (8x8) were in error by no 80

04 | more than .1 KW/FT nominal MAPHLGR limit 8.52 KW/FT 80

05 | 80

06 | 80

RO 76-02

SYSTEM CODE		CAUSE CODE		COMPONENT CODE					PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER			VIOLATION	
07	Z	Z	A	Z	Z	Z	Z	Z	N	Z	9	9	9	N	
7	8	9	10	11	12				17	43	44			47	48

CAUSE DESCRIPTION

08 | Interpolation from Technical Specification curves without grid or breakpoints. 80

09 | 80

10 | 80

RO 76-02

FACILITY STATUS		% POWER		OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
11	E	0	9	4				Z	Routine Review				
7	8	9	10	12	13				44	45			

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE				
12	Z	Z	N/A						N/A			
7	8	9	10	11				44	45			

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION	
13	0	0	0	Z	N/A
7	8	9	11	12	13

PERSONNEL INJURIES

NUMBER		DESCRIPTION		
14	0	0	0	N/A
7	8	9	11	12

XXXX OFF-SITE CONSEQUENCES Probable
NONE

15 | 80

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION	
16	Z	NONE	
7	8	10	

PUBLICITY

17 | NONE 80

8302170559 760303
PDR ADOCK 05000220
S PDR

ADDITIONAL FACTORS

18 | Due to the small error and the degree of conservatism present no hazard was presented 80

to the General Public.

19 | 80

NAME: T. Dente

PHONE: 315-343-2110

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

March 3, 1976

Mr. James P. O'Reilly
Directorate of Regulatory Operations
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pa. 29406

RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Report 76-02 through 76-06 which documents the Reportable Occurrences for February 1976.

This report conforms to the requirements of Regulatory Guide 1.16, Revision 2 and was completed within the intent of the Licensee Event Report Instruction Booklet 00E-SS-001, dated October 1974, revised December 24, 1974. Due to the minimal significance category of the report, no supplemental report is included.

Very truly yours,

Original signed by R.R. Schneider

R.R. Schneider
Vice President -
Electric Operations

TJD/mm

Enc. 3 copies

cc: K.R. Goller (30 copies)

2549