

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

DATE: December 29, 1975

SUBJECT: Abnormal Occurrence Report No. 50- 220 75- 39
(10 Day Letter)

The enclosed Abnormal Occurrence Report is being submitted in accordance with Technical Specification Section 6.

TO: James P. O'Reilly
Directorate of Regulatory Operations
Region 1
631 Park Avenue
King of Prussia, Pa. 19406

FROM: Niagara Mohawk Power Corporation
Nine Mile Point - James A. FitzPatrick Site

P.O. Box #32
Lycoming, New York 13093

Docket No. 50- 220

REFERENCE: License DPR- 63

Report No.: 50- 220 /75- 39

Report Date: 12/29/75

Occurrence Date: 11/23/75 - 11/29/75

Facility: NY NMP #1

Identification of Occurrence:

Failure to analyze stack cartridge weekly which is required by Environmental Technical Specification 2.4.4.I B.

8302180060 751229
PDR ADOCK 05000220
S PDR

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

Conditions Prior to
Occurrence:

_____	Steady State Power	_____	Routine Shutdown
_____	Hot Standby	_____	
_____	Cold Shutdown	_____	Load Changes
X _____	Refueling Shutdown	_____	
_____	Routine Startup	_____	Other

Description of the Occurrence:

During a routine review of the stack release of iodines and particulates with half lives greater than 8 days, it was discovered that there was no stack sample change and analysis during the week of 11/23/75 - 11/29/75 as required by Environmental Technical Specifications 2.4.4. IB.

Apparent Cause of the Occurrence:

_____	Design	_____	Procedure
_____	Manufacture	_____	Unusual Service Condition
_____	Installation/	_____	
_____	Const.	_____	
X _____	Operator	_____	Component Failure
		_____	Other (Specify)

Analysis of Occurrence:

Sample analysis prior to and after this week were on 11/21/75 and 12/1/75 respectively. Release rates of iodines and particulates with half-lives greater than 8 days were 3.87×10^{-3} uc/sec and 7.49×10^{-3} uc/sec for the 11/21/75 and 12/1/75 samples respectively ($\leq 1\%$ of release limit).

Corrective Action:

Technical Specification and procedure requirements have been reviewed with the technician responsible for the sample analysis, to ensure adherence to Technical Specification requirements.

Failure Data:

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 Erie Boulevard, West
Syracuse, New York
13202

December 29, 1975

Mr. James P. O'Reilly
Directorate of Regulatory Operations
Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406

RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1
Environmental Technical Specifications Section 5.6, we hereby submit
the following Abnormal Occurrence Report, 75-39.

Sincerely yours,



R.R. Schneider
Vice President
Electric Operations

TJP/mm

Enc. 3 copies

cc: Mr. K.R. Goller (30 copies)

