

LICENSEE EVENT REPORT

CONTROL BLOCK:
1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME														LICENSE NUMBER										LICENSE TYPE					EVENT TYPE	
01	N	Y	N	M	P	1									4	1	1	1	1	0	1									
7	8	9	14	15	25	26	30	31	32																					

CATEGORY			REPORT TYPE		REPORT SOURCE		DOCKET NUMBER					EVENT DATE					REPORT DATE				
01	CON'T	M	I	L	L	0 5 0 - 0 2 2 0					0 9 1 1 7 5					1 0 0 1 7 5					
7	8	57	58	59	60	61	68	69	74	75	80										

EVENT DESCRIPTION

02	During normal power operation, one APRM (#14) went downscale. Investigation showed																		80
03	that the LPRM inputs to the APRM had lost their power supply. APRM was bypassed.																		80
04	Redundant componetns fully operable.																		80
05																			80
06																			80
07																			80
AOR 75-24																			80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER			VIOLATION		
07	I	A	E	I	N	S	T	R	U	N	G	0	8	0	N
7	8	9	10	11	12	13	14	15	16	17	43	44	45	46	47

CAUSE DESCRIPTION

08	Problem with loose component in power supply. Corrected and returned to service.																		80
09																			80
10																			80

FACILITY STATUS		% POWER		OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					
11	E	0	8	1					a						
7	8	9	10	11	12	13	14	15	16	17	18	19	20		

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE					
12	Z	0	N/A										
7	8	9	10	11	12	13	14	15	16	17	18	19	20

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION										
13	0	0	0	Z	N/A									
7	8	9	10	11	12	13	80							

PERSONNEL INJURIES

NUMBER		DESCRIPTION												
14	0	0	0	0	N/A									
7	8	9	10	11	12	80								

ENVIRONMENTAL CONSEQUENCES Probable

15	None																		80
----	------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION												
16	Z	N/A												
7	8	9	10	80										

PUBLICITY

17	None																		80
----	------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

ADDITIONAL FACTORS

18	None																		80
----	------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

19																			80
----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

8302180129 751001
PDR ADOCK 05000220
S PDR

NAME: Thomas J. Dente

PHONE: (315) 343-2110

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

October 3, 1975

Mr. James P. O'Reilly
Directorate of Regulatory Operations
Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406


RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Reports 75-24 thru 75-28 which document the Abnormal Occurrences for September, 1975.

These reports conform to the requirements of Regulatory Guide 1.16, Revision 2 and were completed within the intent of the Licensee Event Report Instruction Booklet 00E-SS-001, dated October 1974, revised December 24, 1974. Due to the minimal significance category of the reports, no supplemental report is included.


Very truly yours,


R.R. Schneider
Vice President -
Electric Operations

TJD/mm

Enc. 3 copies

cc: K.R. Goller (30 copies)



10771