

NIAGARA MOHAWK POWER CORPORATION

NIAGARA MOHAWK

300 ERIE BOULEVARD WEST
SYRACUSE, N.Y. 13202

April 3, 1973

Mr. James P. O'Reilly
United States Atomic Energy Commission
Region I, Division of Compliance
970 Broad Street
Newark, New Jersey 07107


Dear Mr. O'Reilly:

Re: Provisional Operating License: DPR-17
Docket No.: 50-220

Regarding your letter concerning the failure of Westinghouse Models DB-25, DB-50, and DB-75 circuit breakers, I am pleased to inform you that Nine Mile Point Nuclear Station, Unit No. 1 has not installed any of these breakers in the engineered safeguard systems or other safety systems.

The results of the investigation into this matter also shows that the above make and model of Westinghouse circuit breaker employing over-current trip time delay devices is not used in any system of Nine Mile Point Nuclear Station, Unit No. 1.

Very truly yours,


R. R. Schneider
Vice-President Operations

RRS:cm

8302280129 730425
PDR ADOCK 05000220
G PDR

*Requing
50-220*