LICENSEE EVENT REPORT

CONTROL BLOCK: [1 6] (PLEASE PRINT ALL REQUIRED INFORMATION)

	LICENSEE NAME	LICENSE NUMBER	LICENSE TYPE	EVENT TYPE
01	NYNMP1	– –	4 1 1 1 1	0 1
7 8 9	14	15 25	26 30	31 32

	CATEGORY	REPORT TYPE	REPORT SOURCE	DOCKET NUMBER	EVENT DATE	REPORT DATE
01 CON'T	M I	L	L	0 5 0 – 0 2 2 0	0 7 2 5 7 5	0 8 0 4 7 5
7 8	57 58	59	60	61 68	69 74	75 80

EVENT DESCRIPTION

02 Environmental Technical Specifications requires an Environmental Sample (Milk Sample)
03 be collected and analysed within 8 days of collection. Analysis was not completed
04 until 9 days following collection.
05
06 AOR 75-20

	SYSTEM CODE	CAUSE CODE	COMPONENT CODE	PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER	VIOLATION
07	Z Z	d	Z Z Z Z Z Z	Z	Z 9 9 9	N
7 8 9	10	11	12 17	43	44 47	48

CAUSE DESCRIPTION

08 The sample was sent to the lab via ground transportation. In the future, it will
09 be sent by air. Eberline Corporation contacted and told of speed requirements.
10

	FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
11	E	0 8 0		a	Review by Supervisor
7 8	9	10 12	13 44	45	46 80

	FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE
12	Z	Z	N/A	
7 8	9	10	11 44	45 80

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION
13	0 0 0	Z	N/A
7 8 9	11	12	13 80

PERSONNEL INJURIES

	NUMBER	DESCRIPTION
14	0 0 0	N/A
7 8	11	12 80

~~XXXXXX~~ CONSEQUENCES Probable

15 None

LOSS OR DAMAGE TO FACILITY

	TYPE	DESCRIPTION
16	Z	N/A
7 8 9	10	80

PUBLICITY

17 None

8303110276 750804
PDR ADOCK 05000220
S PDR

ADDITIONAL FACTORS

18 The results of the analysis indicated I-131 well below limits.
19

NAME: T.J. Dente PHONE: (315) 343-2110

GPO 881-667

NIAGARA MOHAWK POWER CORPORATION

NIAGARA MOHAWK

300 ERIE BOULEVARD WEST
SYRACUSE, N.Y. 13202



August 4, 1975

Mr. James P. O'Reilly
Directorate of Regulatory Operations
Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406

RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Reports 75-18 thru 75-20 which document the Abnormal Occurrences for July 1975.

These reports conform to the requirements of Regulatory Guide 1.16, Revision 2 and were completed within the intent of the Licensee Event Report Instruction Booklet 00E-SS-001, dated October, 1974, revised December 24, 1974. Due to the minimal significance category of the reports, no supplemental report is included.

Very truly yours,

R.R. Schneider

R.R. Schneider
Vice President
Electric Operations

TJD/mm

Enc. 3 copies

cc: K.R. Goller (30 copies)

COPY SENT REGION 1

8639