

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

* LICENSEE NAME						LICENSE NUMBER						LICENSE TYPE					EVENT TYPE						
0	1	N	Y	N	M	P	1			-				-		4	1	1	1	1	0	1	
7	8	9					14	15							25	26					30	31	32

CONT		CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER				EVENT DATE			REPORT DATE						
0	1	M	I	L	L	0	5	0	-	0	2	2	0	0	7	0	4	7	5
7	8	57	58	59	60	61							68	69					74
														75					80

[illegible]

02	During routine operations, the emergency condenser vent radiation monitor went	80
03	upscale isolating the system as designed. Investigation revealed no high radiation	80
04	zone and a failed component in the monitor.	80
05		80
06		80
08		80
	AOR 75-18	80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE						COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION	
0	7	S	H	E	I	N	S	T	R	U	N	G	O	8	O	N	
7	8	9	10	11	12					17	43	44			47	48	

CAUSE DESCRIPTION

08	Apparently the high temperature environment caused the failure of a component in	80
09	the monitor. The monitor was replaced. Redundant loop verified operational.	80
10		80

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
11	E	080				a			
7	8	9	10	12	13	44	45	46	80
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE	
12	Z	Z		N/A					
7	8	3	10	11	44	45			80

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION
1	3	0 0 0	Z	N/A

PERSONNEL INJURIES

NUMBER				DESCRIPTION
1	4	0	0	N/A

POSITIVE CONSEQUENCES Probable

15	None
7 8 9	80

LOSS OR DAMAGE TO FACILITY

TYPE			DESCRIPTION
1	5	7	N/A

PUBLICITY

17	None	PLR ADDUCK 05000220
7 8 9		S PDR

ADDITIONAL FACTORS

7	8	9	None	
---	---	---	------	--

NAME: T.J. Dente

PHONE (315) 343-2110

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

August 4, 1975

Mr. James P. O'Reilly
Directorate of Regulatory Operations
Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406


RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Reports 75-18 thru 75-20 which document the Abnormal Occurrences for July 1975.

These reports conform to the requirements of Regulatory Guide 1.16, Revision 2 and were completed within the intent of the Licensee Event Report Instruction Booklet OOE-SS-001, dated October, 1974, revised December 24, 1974. Due to the minimal significance category of the reports, no supplemental report is included.

Very truly yours,



R.R. Schneider
Vice President
Electric Operations

TJD/mm

Enc. 3 copies

cc: K.R. Goller (30 copies)



9360