

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME 01 N Y N M P 1														LICENSE NUMBER 15 - 25										LICENSE TYPE 26 4 1 1 1 1					EVENT TYPE 31 0 1 32	
01 CONT		CATEGORY 57 M 1 58		REPORT TYPE 59 L 60		REPORT SOURCE 61 L 62		DOCKET NUMBER 61 0 5 0 - 0 2 2 0 68										EVENT DATE 69 0 4 0 5 7 5 74					REPORT DATE 75 0 5 0 3 7 5 80							

EVENT DESCRIPTION

02 During surveillance testing, RE-18A Rx Level Lo-Lo-Lo was found to actuate at 131 inches
 03 of H₂O rather than 128.5 inches of water. Redundant sensors available and operable.
 04 Instrument appears to have drifted - Instrument recalibrated to 128.5" of water and
 05 tested.
 06 AOR 75-06

SYSTEM CODE 07 I B		CAUSE CODE 11 E		COMPONENT CODE 12 I N S T R U 17				PRIME COMPONENT SUPPLIER 43 A		COMPONENT MANUFACTURER 44 B O S O 47				VIOLATION 48 N	
-----------------------	--	--------------------	--	-------------------------------------	--	--	--	----------------------------------	--	---	--	--	--	-------------------	--

CAUSE DESCRIPTION

08 Set Point Drift
 09
 10

FACILITY STATUS 11 E		% POWER 10 0 9 4 12 13		OTHER STATUS 44		METHOD OF DISCOVERY 45 b		DISCOVERY DESCRIPTION 46			
FORM OF ACTIVITY RELEASED 12 Z		CONTENT OF RELEASE 10 Z		AMOUNT OF ACTIVITY 11 Z		LOCATION OF RELEASE 44 Z		45			

PERSONNEL EXPOSURES

NUMBER 13 0 0 0		TYPE 12 Z		DESCRIPTION 13 Z	
--------------------	--	--------------	--	---------------------	--

PERSONNEL INJURIES

NUMBER 14 0 0 0		DESCRIPTION 12 Z	
--------------------	--	---------------------	--

CONSEQUENCES Probable

15 None as redundant component available and operable.

LOSS OR DAMAGE TO FACILITY

TYPE 16 Z		DESCRIPTION 10 None	
--------------	--	------------------------	--

PUBLICITY

17 None

ADDITIONAL FACTORS

18 None

19

NAME: T.J. Dente

PHONE: (315) 343-2110

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD WEST
SYRACUSE N Y 13202

May 6, 1975

Mr. James P. O'Reilly
Directorate of Regulatory Operations
Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia. 19406


RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Report 75-6, 75-7, 75-8, and 75-9 which document the Abnormal Occurrences for April 1975.

These reports conform to the requirements of Regulatory Guide 1.16, Revision 2 and were completed within the intent of the Licensee Event Report instruction booklet 00E-SS-001, dated October, 1974, revised December 24, 1974. Due to the Minimal significance category of the reports, no supplemental report is included.

Very truly yours,


R.R. Schneider
Vice President
Electric Operations

TJD/mm

Enc. 3 copies

cc: 30 copies to K.R. Goller

5552