

July 6, 1984
(NMP2L 0105)


Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report in accordance with 10CFR50.55(e) for the problem concerning feedwater valves furnished by Velan Valve Corporation (55(e)-84-22). This problem was reported via telecon to W. Lazerus of your staff on June 13, 1984.

Sincerely,


T. E. Lempges
Vice President
Nuclear Generation

TEL/TRL:djm
Enclosure

xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

R. Gramm (NRC Resident)

8407190394 840706
PDR ADOCK 05000410
S PDR

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT UNIT 2
DOCKET NO. 50-410

Interim Report for a Problem
Concerning Velan Valves - Feedwater System
(55(e)-84-22)

Description of the Problem

During a review of documentation, it was observed that the certified material test reports (CMTRs) provided by the valve manufacturer did not document the test coupon heat treatment duration and temperature as required by ASME Section III, NB-2211. Further inquiry revealed that the heat treatment of the test coupons was in fact not performed.

The matter is still being investigated and a final report will be submitted by November 26, 1984.

NOV 27 11 11 AM '84
100-10-10-11