

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME 01 I L D R S 2														LICENSE NUMBER 00-000000-00										LICENSE TYPE 41111					EVENT TYPE 03								
CATEGORY 01 CONT														REPORT TYPE L		REPORT SOURCE L		DOCKET NUMBER 050-0237										EVENT DATE 032576					REPORT DATE 042376				

EVENT DESCRIPTION

02 DURING A REFUELING OUTAGE LOCAL LEAK-RATE TEST, FEEDWATER ISOLATION CHECK VALVES																																																																															
03 2-220-58BE-62B EXCEEDED THE 29.381 SCFH TECH SPEC LIMIT (695.5 SCFH & 88,846																																																																															
04 SCFH RESPECTIVELY). "A" FEEDWATER LINE CHECK VALVES PASSED THE LLRT SATISFAC-																																																																															
05 TORILY (2.8 & 14.1 SCFH RESPECTIVELY). REDUNDANT VALVES WERE AVAILABLE AND OPERABLE																																																																															
06 DURING OPERATION. THIS IS A REPETITIVE OCCURRENCE. (50-237/1976-18)																																																																															

SYSTEM CODE 07 CH		CAUSE CODE E		COMPONENT CODE VALVEX				PRIME COMPONENT SUPPLIER A		COMPONENT MANUFACTURER C1615				VIOLATION Y	
----------------------	--	-----------------	--	--------------------------	--	--	--	-------------------------------	--	---------------------------------	--	--	--	----------------	--

CAUSE DESCRIPTION NA

08 EXAMINATION AND OVERHAULING OF THESE VALVES HAS NOT YET BEEN COMPLETED.																																																																															
09 AN UPDATE REPORT WILL BE SUBMITTED UPON COMPLETION OF REPAIRS AND RE-TESTING.																																																																															
10 BOTH VALVES ARE 18-INCH TILTING-DISC, PRESSURE SEAL CHECK VALVES, MODEL 973, MANU-																																																																															

FACILITY STATUS 11 H		% POWER 000		OTHER STATUS NA		METHOD OF DISCOVERY B		DISCOVERY DESCRIPTION NA	
FORM OF ACTIVITY RELEASED 12 Z		CONTENT OF RELEASE Z		AMOUNT OF ACTIVITY NA		LOCATION OF RELEASE NA			

PERSONNEL EXPOSURES

NUMBER 13 000		TYPE Z		DESCRIPTION NA	
------------------	--	-----------	--	-------------------	--

PERSONNEL INJURIES

NUMBER 14 000		DESCRIPTION NA	
------------------	--	-------------------	--

OFFSITE CONSEQUENCES

15 NA	
-------	--

LOSS OR DAMAGE TO FACILITY

TYPE 16 Z		DESCRIPTION NA	
--------------	--	-------------------	--

PUBLICITY

17 NA	
-------	--

ADDITIONAL FACTORS CAUSE DESCRIPTION (CONTINUED)

18		FACTURED BY CRANE CO.	
----	--	-----------------------	--

8303310158 760629
PDR ADOCK 05000237
PDR

19		S	
----	--	---	--

NAME: K. D. LEITZELL

PHONE: EXT. 421



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920


BBS Ltr. #330-76

April 23, 1976



Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Enclosed please find Reportable Occurrence number 50-237/1976-18.
This report is being submitted to your office in accordance with the
Dresden Nuclear Power Station Technical Specifications, Section 6.6.B.


B. B. Stephenson
Station Superintendent
Dresden Nuclear Power Station

BBS: smp

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
File/NRC

4256