

James G. Keppler Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Recopied Date 11-17-75
or
Telegressed: GE 12:50 P.M.
DC _____
By KC

cc:

Bernard C. Rusche, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

60-237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with REGULATORY DIVISION of
your office at 0855 hrs ~~standing~~ concerning QUARTERLY CLOSURE
TIMING OF IC MAIN STEAM ISOLATION VALVE IN WHICH THE
CLOSURE TIME WAS FOUND AT 2.7 SECONDS. (TECH SPEC LIMIT
3-5 SECONDS.) THE OCCURRENCE WAS NOTED AT 0330 HRS, 11/16/75
AND THE VALVE REPAIRED BY 1730 HRS, 11/16/75 AFTER THE UNIT
WAS SHUTDOWN. ALL OTHER VALVES WERE OPERABLE AT THE TIME.

8303310601 751117
PDR ADOCK 05000237
S PDR

To Call:

GE - 5-858-2660x16 (auto)
DC - 9-1-301-492-7617 (auto) - on 6
WU - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2920/2921x212

Rec'd 11/17/75