

**GULF STATES UTILITIES COMPANY**



IVER BEND STATION    POST OFFICE BOX 220    ST FRANCISVILLE, LOUISIANA 70775  
AREA CODE 804    635-6094    345-6551

February 28, 1992  
RBG- 36,562  
File Nos. G9.5, G9.25.1.5

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Gentlemen:

River Bend Station - Unit 1  
Docket No. 50-458

Enclosed is the River Bend Station Annual Operating Report for 1991. This report is submitted in accordance with Technical Specifications 6.9.1.4 and 6.9.1.5 of Appendix A to River Bend Station (RBS) License Number NPF-47.

Sincerely,

W.H. Odell  
Manager - Oversight  
River bend Nuclear Group

JAE/LLD/BMB/kvm

Enclosure

cc: U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

NRC Sr. Resident Inspector  
P.O. Box 1051  
St. Francisville, LA 70775

Mr. D. V. Pickett  
U.S. Nuclear Regulatory commission  
11555 Rockville Pike  
Rockville, MD 20852

090137

9203090432 911231  
PDR ADOCK 05000458  
R PDR

GULF STATES UTILITIES  
RIVER BEND STATION  
ANNUAL OPERATIONS REPORT  
FOR  
1991

## TABLE OF CONTENTS

- 1.0 INTRODUCTION
- 2.0 OCCUPATIONAL RADIATION SUMMARY REPORT
- 3.0 SRV HISTORY
- 4.0 REACTOR COOLANT SYSTEM SPECIFIC ACTIVITY  
ANALYSIS

## ANNUAL OPERATING REPORT

### 1.0 INTRODUCTION

This River Bend Station Annual Operating Report for 1991 is submitted in accordance with applicable reporting requirements of Technical Specifications 6.9.1.4 and 6.9.1.5, of Appendix A to River Bend Station (RBS) License Number NPF-47. This routine operating report covering operation of the unit during the previous calendar year also complies with applicable sections of USNRC Regulatory Guide 1.16, "Reporting of Operating Information - Appendix A Technical Specifications".

## 2.0 OCCUPATIONAL RADIATION SUMMARY REPORT

Enclosed in this section is a report on Occupations Radiation Exposure for River Bend Station personnel for the year 1991 as required by 10CFR20.407, Regulatory Guide 1.16, and Technical Specification section 6.9.1.5a of Appendix A to River Bend Station Operating License Number NPF-47.

The enclosed table is developed from pocket dosimeter data. The River Bend Station TLD total for 1991 is 127 man-rem.

# 1991 USNRC ANNUAL REG GUIDE 1-16 REPORT GULF STATES UTILITIES - NRC LICENSE

P. O. Box 220  
St. Francisville, LA 70775

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (>100.0 MREM)				TOTAL MAN-REM		
	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT WORKERS & OTHERS	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT WORKERS & OTHERS	
REACTOR OPERATIONS & SURVEILLANCE							
MAINTENANCE PERSONNEL	5.6	0.3	2.1	2.361	0.035	0.710	
OPERATING PERSONNEL	24.8	0.0	1.1	14.734	0.000	0.140	
HEALTH PHYSICS PERSONNEL	20.2	0.0	7.6	12.385	0.000	3.359	
SUPERVISORY PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
ENGINEERING PERSONNEL	0.7	0.8	4.3	0.150	0.160	1.454	
ROUTINE MAINTENANCE							
MAINTENANCE PERSONNEL	6.9	0.0	7.4	2.565	0.000	1.813	
OPERATING PERSONNEL	2.2	0.0	0.0	0.840	0.000	0.000	
HEALTH PHYSICS PERSONNEL	0.9	0.0	0.2	0.600	0.000	0.100	
SUPERVISORY PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
ENGINEERING PERSONNEL	1.2	1.2	0.9	0.250	0.235	0.110	
INSERVICE INSPECTION							
MAINTENANCE PERSONNEL	2.2	0.7	0.7	0.915	0.070	0.115	
OPERATING PERSONNEL	0.6	0.0	0.0	0.205	0.000	0.000	
HEALTH PHYSICS PERSONNEL	1.0	0.0	1.0	0.235	0.000	0.450	
SUPERVISORY PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
ENGINEERING PERSONNEL	0.8	0.5	3.6	0.195	0.130	1.830	
SPECIAL MAINTENANCE							
MAINTENANCE PERSONNEL	62.1	0.0	46.9	34.182	0.000	32.880	
OPERATING PERSONNEL	5.5	0.0	1.3	2.327	0.000	0.460	
HEALTH PHYSICS PERSONNEL	9.9	0.0	5.0	6.758	0.000	2.217	
SUPERVISORY PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
ENGINEERING PERSONNEL	7.3	3.5	3.2	1.577	0.914	0.660	
WASTE PROCESSING							
MAINTENANCE PERSONNEL	0.1	0.0	1.8	0.025	0.000	0.805	
OPERATING PERSONNEL	0.9	0.0	5.6	0.225	0.000	3.165	
HEALTH PHYSICS PERSONNEL	0.9	0.0	0.2	0.672	0.000	0.105	
SUPERVISORY PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
ENGINEERING PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
REFUELING							
MAINTENANCE PERSONNEL	0.1	0.0	0.1	0.010	0.000	0.015	
OPERATING PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
HEALTH PHYSICS PERSONNEL	0.1	0.0	0.0	0.020	0.000	0.000	
SUPERVISORY PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
ENGINEERING PERSONNEL	0.0	0.0	0.0	0.000	0.000	0.000	
TOTALS*							
MAINTENANCE PERSONNEL	77	1	59	40.058	0.105	36.338	
OPERATING PERSONNEL	34	0	8	18.331	0.000	3.765	
HEALTH PHYSICS PERSONNEL	33	0	14	20.670	0.000	6.231	
SUPERVISORY PERSONNEL	0	0	0	0.000	0.000	0.000	
ENGINEERING PERSONNEL	10	6	12	2.172	1.439	4.054	
GRAND TOTALS	154	7	93	81.231	1.544	50.388	

\*FIGURES REPRESENT THE ACTUAL NUMBER OF PERSONNEL EXPOSED.

*E. M. Cargill*  
E. M. CARGILL, DIRECTOR - RADIOLOGICAL PROGRAMS



### 3.0 SAFETY RELIEF VALVE HISTORY

The operating and spare safety/relief valves did not actuate during 1991. No scrams occurred during 1991. STP-202-0602, "ADS RELIEF VALVE OPERABILITY TEST", was not performed in 1991. Therefore, no actuation events are submitted. Also, the 16 installed safety/relief valves were not removed from service during 1991. Therefore, no 1991 maintenance activity of the presently installed safety/relief valves is submitted.

Operating safety/relief valve tail pipe temperatures have not increased significantly during 1991. Approximately 10 out of 16 safety/relief valve tail pipe temperatures are between 200 degrees to 235 degrees Fahrenheit indicating some leakage.

4.0

REACTOR COOLANT SYSTEM SPECIFIC ACTIVITY  
ANALYSIS

During the year of 1991, analysis of the specific activity of the primary coolant indicated that the Limited Condition of operation of Specification 3.4.5, "Specific Activity" of the River Bend Technical Specification was never exceeded.

As delineated by Technical Specification section 6.9.1.5.c of Appendix A to River Bend License Number NPF-47, no additional information is required or enclosed.