

James G. Kappler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopied
or
Unrecorded:

Date 9-29-75
CE 1:25 PM
DC
By G.T.

cc:

Bernard C. Rusche, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

60-237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Mr. Phil Johnson of
your office at 11:50 AM hrs this date concerning the failure
of the HPCI turbine to shut down. On
investigating it was found the Turps solenoid
coil was no good.

8303310633 750929
PDR ADOCK 05000237
PDR
S

To Call:

GE - 5-858-2660x16 (auto) - on 6
EC - 9-1-301-492-7617 (auto)
WU - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (original)

4/29 Rec'd 1/19 <9
E. E. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2920/2921x212