

BOSTON EDISON COMPANY
800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199

WILLIAM D. HARRINGTON
SENIOR VICE PRESIDENT
NUCLEAR

July 16, 1984
BECO 84-107

Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

License No. DPR-35
Docket No. 50-293

Withdrawal of Proposed Change
to Control Rod Drive Weekly
Surveillance Technical Specification

Dear Sir:

Pursuant to 10CFR2.107, it is requested that the Technical Specification change proposed by letter dated September 12, 1983 (BECO 83-238), concerning control rod drive weekly surveillance testing at the Pilgrim Nuclear Power Station be withdrawn from consideration. Further communication with the General Electric Company has determined that the proposed alternative weekly exercise is acceptable only for control rod drives with improved collet retainer tubes. Because not all control rod drives at Pilgrim have the improved collet retainer tubes, it is requested that this proposed change be withdrawn at this time.

Very truly yours,

W D Harrington

DMV/kmc

8407200174 840716
PDR ADOCK 05000293
P PDR

*A001
10*